

US Army Corps

of Engineers ®

Papillion Creek and Tributaries Lakes, Nebraska

General Reevaluation Report

Appendix A-1. Dam Site 10 Hydrology



June 2021

Omaha District Northwestern Division Hydrologic Engineering Branch Engineering Division THIS PAGE INTENTIONALLY LEFT BLANK

Executive Summary

This Hydrology Appendix for the Papillion general reevaluation report (GRR) study documents the National Economic Development (NED) plan for Dam Site 10 (DS10). Documented as well are other designs leading to the NED used to screen for and justify federal interest. The report also incorporates input from the Tentatively Selected Plan (TSP) and the Agency Decision Milestone (ADM) meetings. Design criteria were generally consistent with the four existing Papillion Creek dams but updated to current USACE standards including Engineering Regulation 1110-8-2(FR), *Inflow Design Floods for Dams and Reservoirs* (USACE, 1991). The nonfederal sponsor was the Papio-Missouri River Natural Resources District (NRD).

This report refers to the designs listed below:

- <u>Original Design</u> USACE 1975 original design (USACE, 1975). This was a dam with a permanent pool.
- <u>TSP Design</u> design presented at the TSP milestone meeting and included both a wet dam and dry dam design. Dam design was built on the Original Design and incorporated some updates to USACE guidance. This included starting at a higher antecedent pool than the Original Design and adopting and updated PMP from another USACE dam in the Papillion Creek watershed. A site-specific PMP was added later in the study.
- <u>ADM Design</u> design presented at the ADM meeting and used to determine federal interest. Included just the dry dam design. The dam design was updated to include both antecedent pool elevations required in ER 1110-8-2(FR), unit hydrograph and loss parameters from the FYRA model (FYRA, 2018), and the spillway design flood was updated with optimized PMP HMR 51&52 precipitation. Future land use conditions were used in the design. Spillway cut and embankment fill quantities had not been finalized.
- <u>After ADM Design</u> design leading up to the National Economic Development (NED) plan design. Best balance of cut and fill. Future land use conditions were used in design.
- <u>NED Design</u> National Economic Development (NED) plan design. This design added a slight modification to the outlet works of the After ADM Design in response to Project Development Team (PDT) review. The conduit outlet invert was raised from 1151.0 ft to 1154.0 ft NAVD88 to elevate the outlet into more stable geology (glacial till). However, the results presented were not significantly sensitive to this change. See Section 18 and Appendix A-1A of this document for a discussion of these results.

DS10 is designed only as a dry dam without a permanent multipurpose pool in the ADM and After ADM Designs. The dry dam design was developed with guidance from the Omaha District River and Reservoir Engineering section and based on research of other dry dams in the Omaha District and general reservoir sedimentation science. The design consists of a lower level box culvert outlet set near the bottom of the pool with a removable trash rack and concrete pad to accommodate clean-out with a skid loader or similar machinery. This outlet design passes sediment more efficiently to better maintain flood storage, allows for easier cleanout of the outlet works, and reduces downstream erosion. The box culvert was sized to begin storing water with events larger than the 50-percent annual exceedance probability (AEP, ~2 year event) flow.

The After ADM (Balanced) Design is the focus of this report. This design lead to the NED Plan design presented in Section 18. The NED design presented is still tentative and includes only a simplified hydrologic loading curve and not a risk-based design, which will be completed in a later phase of the study. Refer to the Risk to Life Safety Appendix (Appendix L) for the simplified hydrologic loading curve.

In the ADM Design (the design used to determine federal interest), real estate pools were not yet informed by the cut-and-fill balance analysis. What was felt to be a conservatively high flowage easement pool was assumed for real estate cost calculations for the dry dam at that point in the study. The actual real estate pool needed for the dry dam with a cut-and-fill balance considered was higher (1205.6 ft-NAVD88) than that used in the ADM Design (1202.74 ft-NAVD88). This was due to a decrease in spillway width in the design to reduce cut.

The probable maximum precipitation (PMP) was determined through optimization in HEC-HMS version 4.4beta using HMR52 Storm. Optimization considered maximization of peak flow, inflow volume, and pool elevation.

Unit hydrographs were determined from the existing FYRA 2018 models which were calibrated to three recent events with radar precipitation data. These unit hydrographs were then peaked at the dam by 125, 150 and 175 percent. The 125 percent peaking was used for the Standard Project Flood (SPF) reservoir design flood modeling and the 150 and 175 percent peaking was used for the PMF modeling used in spillway optimization. Frequency events were modeled without unit hydrograph peaking.

Both the Most Reasonable (MR PMF) and Reasonable High PMF (RH PMF) were routed through the dam to determine spillway and dam embankment design. Dam embankment height was determined as the highest of two alternatives: the RH PMF maximum pool elevation or the MR PMF pool elevation plus three feet. In the case of this site, the MR PMF plus three feet resulted in the highest elevation and was used to set the dam height. The MR and RH PMFs differ in their soil loss rates, unit hydrograph peaking, and Probable Maximum Precipitation (PMP) to better incorporate uncertainty.

Eleven different spillway crest elevation and width combinations were used to help optimize the spillway and dam embankment height cut-and-fill to reduce the costs at the site for quantities.

Figure E1 shows the NED plan design. Table E1 and E2 list pertinent information for the NED design. Figure E2 shows the NED dam location and design pools.



Figure E1. NED Design

Table E1. Design	Pertinent	Information	(Precipitation)
				,

Precipitation (in)				
Reasonable High Probable Maximum Precipitation (RH PMP) - 1.05*MR PMP				
72-hour total depth (in)	39.1			
1-hour max depth (in)	15.3			
5-min max depth (in)	1.68			
Most Reasonable Probable Maximum Precipitation (MR PMP)				
72-hour total depth (in)	37.2			
1-hour max depth (in)	14.6			
5-min max depth (in)	1.6			
Reservoir Design Flood Precipitation - SPS (Dry Dam Design)				
96-hour total depth (in)	15.81			
1-hour maximum depth (in)	3.75			
5-min max depth (in)	0.31			

Design Events						
			NED Plan			
	ADM Design	After ADM	Design (Dry			
	(Dry Dam)	(Dry Dam)	Dam)			
Spillway Design Flood - RH PMF						
Peak inflow (cfs)	43,100	43,100	43,100			
Peak outflow (cfs)	28,000	15,800	15,900			
Inflow volume (AF)	6727	6727	6727			
Spillway Design Flood - MR PMF						
Peak inflow (cfs)	36,900	36,900	36,900			
Peak outflow (cfs)	24,500	13,500	13,700			
Inflow volume (AF)	6092	6092	6092			
Reservoir Design Flood						
Peak inflow (cfs)	7,490	7,490	7,490			
Peak outflow (cfs)	1,480	1,480	1,480			
Inflow volume (AF)	1,944	1,944	1,944			
Elevatio	ns (ft-NAVD88)					
			NED Plan			
	ADM Design	After ADM	Design (Dry			
	(Dry Dam)	(Dry Dam)	Dam)			
Top of Dam	1201.8	1207.4	1207.4			
RH PMF Pool	1199.7	1205.6	1205.6			
MR PMF Pool	1198.8	1204.4	1204.4			
Spillway Crest	1187.6	1191.6	1191.6			
Top of Flood Control Pool	1184.6	1184.6	1185			
Top of Multipurpose Pool	-	-	-			
Outlet Invert Elevation	1151.0	1151.0	1154.0			
Min Pool Elevation	1151.0	1151.0	1151.0			
Sto	orage (AF)					
			NED Plan			
	ADM Design	After ADM	Design (Dry			
	(Dry Dam)	(Dry Dam)	Dam)			
Top of Dam	4,111	5,726	5,726			
RH PMF Pool	3,587	5,172	5,172			
MR PMF Pool	3,376	4,821	4,821			
Spillway Crest	1,415	1,992	1,992			
Top of Flood Control Pool	1,055	1,055	1,097			
Top of Multipurpose Pool	-	-	-			
Outlet Invert Elevation	0	0	0.3			

Table E2. Design Pertinent Information (ADM & After ADM Designs)



Figure E2. Project Location and Pools

TABLE OF CONTENTS

APPENDICES

Appendix A-1A: Sensitivity Analysis: Increase in Outlet Conduit Invert Appendix A-1B: Rainfall Hyetographs

LIST OF FIGURES

Figure 1. DS10 Location	2
Figure 2. Updated DS10 Capacity Curve	4
Figure 3. Kelly Road Dry Dam Outlet Structure, Aurora, Colorado	6
Figure 4. Dry Dam Lower Level Outlet Rating Curve	7
Figure 5. Adopted reservoir design storm for DS10	9
Figure 6. PMP Orientation Over Watershed	13
Figure 7. Subbasin LP-17 HMR 51&52	14
Figure 8. Subbasin LP-18 HMR 51&52	14
Figure 9. Subbasin LP-19 HMR 51&52	15
Figure 10. Subbasin LP-20A HMR 51&52	15
Figure 11. HEC-HMS Model	16
Figure 12. 1975 DM 30-minute Unit Hydrographs	20
Figure 13. 30-Minute Unit Hydrograph Comparisons	21
Figure 14. Adopted 30-Minute Unit Hydrographs	21
Figure 15. Reservoir Design Flood Routing	23
Figure 16. PMF Comparison	27
Figure 17. Dry Dam Design (ADM Design)	29
Figure 18. Dry Dam Design (After ADM Design)	30
Figure 19. After ADM Design - Starting Pool Top of Flood Control	32
Figure 20. After ADM Design - Starting Pool 5-Day Drawdown	33
Figure 21. Existing Conditions Frequency Event Outflows and Pool Elevations	36
Figure 22. Future Conditions Frequency Event Outflows and Pool Elevations	37
Figure 23. Decreased Level of Protection Scenario	38
Figure 24. NED Design	40
Figure 25. NED Outlet Rating Curve	41
Figure 26. NED Spillway Design Flood PMF Routed Over Full Flood Control Pool (O	utlet
Blocked)	43
Figure 27. NED Reservoir Design Flood SPF Routed Over Full Multipurpose Pool (O	utlet
Functional)	44

LIST OF TABLES

Table 1. Dry Dam Lower Level Outlet	8
Table 2. Reservoir Design Storm	9
Table 3. Standard Project Storm for HEC-HMS Model	10
Table 4. HMR 51 Depth-Area-Duration Values	12
Table 5. PMP Optimization Trials	12
Table 6. Comparison of PMP Depths for Various Durations	16
Table 7. Drainage Areas	17
Table 8. Adopted Unit Hydrograph Peak Flows and Parameters	19
Table 9. Soil Losses	22
Table 10. Dam Spillway Crest Elevations and Width Combinations	26
Table 11. Probable Maximum Flood Combinations	26
Table 12. Most Reasonable PMF Spillway Optimization Results	28
Table 13. Reasonable High PMF Spillway Optimization Results	28

Table 14. Pertinent Information (Precipitation)	30
Table 15. Design Pertinent Information (ADM & After ADM Designs)	31
Table 16. NOAA Atlas 14 12-hour Depths	34
Table 17. Existing Conditions Frequency Events	35
Table 18. Future Conditions Frequency Events	35
Table 19. NED Outlet Rating Curve	42

1 Purpose

The purpose of this general reevaluation report (GRR) study was to model flood risk management alternatives in the Papillion Creek watershed. This Appendix documents additional refinement to the hydrologic design of Dam Site 10 (DS10) for the Agency Decision Milestone (ADM). Current USACE standards were used including Engineering Regulation 1110-8-2(FR), Inflow Design Floods for Dams and Reservoirs (USACE, 1991). DS10 was designed as a dry dam without a permanent multipurpose pool. The design presented is still tentative as it includes only a simplified hydrologic loading curve (see the Risk to Life Safety—Appendix L—for curve) and not a risk-based design, which will be completed in a later phase of the study.

The nonfederal project sponsor was the Papio-Missouri River Natural Resources District (NRD).

2 Dam Site

DS10 is located on Thomas Creek north of the Omaha, Nebraska metro area. Thomas Creek is a tributary to the Little Papillion Creek. The dam and reservoir site are primarily in Douglas County, but about one-half of the drainage area is in Washington County. The contributing drainage area to the site is 4.3 square miles (USACE, 1975). The project location is shown in Figure 1 which includes the dam embankment, spillway, 10-percent Annual Exceedance Probability (AEP) pool, and the Reasonable High Probable Maximum Flood (RH PMF) pool elevation. The RH PMF pool is also the flowage easement pool.

3 Vertical Datum

The datum used in this report was NAVD88 unless otherwise stated.

4 Overview of Dry Dam Design

The dry dam design for DS10 was determined through investigation of existing dry dams in the Omaha District. The Omaha District River and Reservoir Engineering (RARE) section was also consulted. The dam project is designed to drain the pool and pass sediment efficiently between events and does not have a permanent pool. This assumption will be verified later in the study due to SMART planning constraints on time and schedule.

The intake invert of the outlet was placed near the bottom of the pool. It was sized to allow the passage of the 50-percent AEP event and facilitate mechanical removal of sediment within the conduit (eg. by means of a skid loader) for cleanout as needed. More details are presented in additional sections of this report.



Figure 1. DS10 Location

5 Dam Designs Overview

The following lists the dam designs considered in the Papillion Creek GRR study. These names are used throughout this report.

- <u>Original Design</u> USACE 1975 original feasibility design (USACE, 1975). This was a dam with a permanent pool.
- <u>TSP Design</u> design presented at the TSP milestone meeting and included both a wet dam and dry dam design. Dam design was built on the Original Design and incorporated some updates to USACE guidance. This included starting at a higher antecedent pool than the Original Design and adopting and updated PMP from another USACE dam in the Papillion Creek watershed. A site-specific PMP was added later in the study.
- <u>ADM Design</u> design presented at the ADM meeting and used to determine federal interest. Included just the dry dam design. The dam design was updated to include both, instead of just one, antecedent pool elevations required in ER 1110-8-2(FR); unit hydrograph and loss parameters from the FYRA model (FYRA, 2018); and the spillway design flood was updated with optimized HMR 51&52 precipitation. Future land use conditions were used in the design. Spillway cut and embankment fill quantities had not been finalized.

- <u>After ADM Design</u> design with cut and fill balance considered. Future land use conditions were used in design.
- <u>NED Design</u> National Economic Development (NED) plan design. This design added a slight modification to the outlet works of the After ADM Design in response to Project Development Team (PDT) review. The conduit outlet invert was raised from 1151 ft to 1154 ft NAVD88 to elevate the outlet into more stable geology (glacial till). However, the results presented were not significantly sensitive to this change. See Section 19 and Appendix A-1A of this document for a discussion of these results.

In addition to these dam designs, the report references the 2018 FYRA hydrology which was used in the modeling of the ADM and After ADM designs. The NRD did not have a dam design for DS10 on Thomas Creek as they did for DS-19 near Gretna, Nebraska.

6 Reservoir Capacity Curve

The reservoir pool capacity curve was determined from 2016 LiDAR data using the Surface Volume tool in ArcMap in Batch mode. One-foot increments were used. Figure 2 shows the updated capacity curve.



Figure 2. Updated DS10 Capacity Curve (datum NAVD88)

7 Outlet Structure

The outlet structure design for the DS10 dry dam was determined through the investigation of outlets for existing dry dams in the Omaha District, consultation with the Omaha District RARE section, and consideration of downstream capacity of the channel to the confluence of Papillion Creek with the Missouri River.

The design is an 8-ft (Span) x 7-ft (Rise) box culvert which begins storing water with events larger than the 50-percent AEP (~2 year event) flow. It also facilitates mechanical sediment removal (eg. by use of a skid loader) as needed. This outlet design passes sediment more efficiently to better maintain flood storage, allows for easier cleanout of the outlet works, and reduces downstream erosion. The curve shown was used through most of the study, so it is provided here in place of the NED design plan curve. The NED outlet rating curve is documented in Section 18. The NED curve is for the same size and shape of outlet, but the outlet is raised three feet.

The 50-percent AEP event was selected as the event to size the outlet works because hydraulic unsteady modeling showed the flow remained within channel to the confluence of Papillion Creek

with the Missouri River. The 50-percent AEP flow immediately below the dam in the existing condition without the dam, determined from unsteady HEC-RAS modeling, is 1,475 cfs. The downstream capacity of the physical channel immediately below the dam is 2,097 cfs based on information from the hydraulics model.

Based on input from the Omaha District RARE section, the proposed design with the 8-ft (Span) x 7-ft (Rise) outlet would be largely self-cleaning in that the more frequent events would pass through with minor detention and carry sediment that would have otherwise been entrained behind the dam. This has the added benefit of decreasing stream degradation downstream in that the water maintains its sediment load instead of becoming "hungry" at the dam outlet and eroding the downstream channel, exposing utilities and eroding into property. This assumption was based on engineering experience. Actual modeling would occur later in the study.

Several outlet sizes were considered during the reservoir design flood modeling to determine the optimum size for the outlet to best approximate the 50-percent AEP event release. Sizes considered were: 6-ft (Span) x 7-ft (Rise), 7-ft (Span) x 6-ft (Rise), 7-ft (Span) x 7-ft (Rise), and 7-ft (Span) x 8-ft (Rise). The 8-ft (Span) x 7-ft (Rise) was selected.

Figure 3 shows the outlet works for the USACE Kelly Road Dry Dam in Aurora, Colorado. This design includes a riser as well as a lower level outlet with a trash rack. This design was presented to the chiefs of Hydrology and the RARE sections in the Omaha District and it was decided to remove the riser from design and increase the size of the lower level outlet. As noted previously, this design passes sediment more efficiently to better maintain flood storage, allows for easier cleanout of the outlet works, and reduces downstream erosion.

Other dry dams investigated were Bull Hook Dam and Scott Coulee near Havre, Montana and Cedar Canyon Dam near Rapid City, South Dakota. The drainage area of these dams varied significantly ranging from 54 to 0.71 square miles. All were built and closed in the 1950s. Reservoir Design Floods varied and included the 1% AEP, the Standard Project Flood (SPF) and a hypothetical event twice the size of the flood of record. Spillway design floods were either the PMF or ten times the flood of record. Sediment pools were designed to contain either 100 years or 50 years of sediment deposition or sediment deposition was not considered due to small sediment loads. The discharge from the lower-level outlet works varied from 49 to 570 cfs and their diameters ranged from 24 to 48 inches. Some of these dams had outlet inverts at the bottom of the pool and others were raised to accommodate sediment storage. Cedar Canyon Dam's outlet invert was set at the top of the 50-year sediment pool which is the design life of the structure.

Figure 4 and Table 1 show rating curves for the lower level outlet produced by the Omaha District Hydraulics section.



Figure 3. Kelly Road Dry Dam Outlet Structure, Aurora, Colorado



Figure 4. Dry Dam Lower Level Outlet Rating Curve

Elev (ft-	Discharge	Elev (ft-		Elev (ft-	
NAVD88)	(cfs)	NAVD88)	Discharge (cfs)	NAVD88)	Discharge (cfs)
1151	0.0	1165	874	1179	1335
1151.5	9.6	1165.5	894	1179.5	1348
1152	27.2	1166	914	1180	1362
1152.5	50.0	1166.5	934	1180.5	1375
1153	77.0	1167	953	1181	1388
1153.5	108	1167.5	972	1181.5	1401
1154	142	1168	991	1182	1414
1154.5	178	1168.5	1009	1182.5	1427
1155	218	1169	1027	1183	1439
1155.5	260	1169.5	1044	1183.5	1452
1156	305	1170	1062	1184	1465
1156.5	351	1170.5	1079	1184.5	1477
1157	400	1171	1095	1185	1489
1157.5	451	1171.5	1112	1185.5	1501
1158	504	1172	1128	1186	1513
1158.5	539	1172.5	1144	1186.5	1525
1159	572	1173	1160	1187	1537
1159.5	603	1173.5	1175	1187.5	1549
1160	632	1174	1191	1188	1561
1160.5	660	1174.5	1206	1188.5	1572
1161	687	1175	1221	1189	1584
1161.5	713	1175.5	1236	1189.5	1595
1162	738	1176	1250	1190	1607
1162.5	763	1176.5	1265	1190.5	1618
1163	786	1177	1279	1191	1629
1163.5	809	1177.5	1293	1200	1800
1164	831	1178	1307	1215	2000
1164.5	853	1178.5	1321		

Table 1. Dry Dam Lower Level Outlet

8 Standard Project Storm

The reservoir design flood (RDF) for DS10 was used to initially set the minimum spillway elevation and was assumed to be the peak elevation of the standard project flood (SPF). The SPF was produced by the standard project storm (SPS) referenced from the 1970s design (USACE, 1975) of the dam. Risk-based considerations are documented separately.

The adopted SPF is shown in Figure 5, Table 2, and Table 3.



Figure 5. Adopted reservoir design storm for DS10

	SPS Depth
Time (Hours)	(in)
0-24	0.31
24-48	1.71
48-54	0.61
54-60	1.62
60-61	0.99
61-62	1.18
62-63	1.48
63-64	3.75
64-65	1.38
65-66	1.09
66-72	1.01
72-96	0.68
Total:	15.81

Table 2. Reservoir Design Storm

Time	Rainfall	Time	Rainfall	Time	Rainfall	Time	Rainfall
(hrs)	(in)	(hrs)	(in)	(hrs)	(in)	(hrs)	(in)
0	0.013	24	0.071	48	0.102	72	0.028
1	0.013	25	0.071	49	0.102	73	0.028
2	0.013	26	0.071	50	0.102	74	0.028
3	0.013	27	0.071	51	0.102	75	0.028
4	0.013	28	0.071	52	0.102	76	0.028
5	0.013	29	0.071	53	0.102	77	0.028
6	0.013	30	0.071	54	0.27	78	0.028
7	0.013	31	0.071	55	0.27	79	0.028
8	0.013	32	0.071	56	0.27	80	0.028
9	0.013	33	0.071	57	0.27	81	0.028
10	0.013	34	0.071	58	0.27	82	0.028
11	0.013	35	0.071	59	0.27	83	0.028
12	0.013	36	0.071	60	0.99	84	0.028
13	0.013	37	0.071	61	1.18	85	0.028
14	0.013	38	0.071	62	1.48	86	0.028
15	0.013	39	0.071	63	3.75	87	0.028
16	0.013	40	0.071	64	1.38	88	0.028
17	0.013	41	0.071	65	1.09	89	0.028
18	0.013	42	0.071	66	0.168	90	0.028
19	0.013	43	0.071	67	0.168	91	0.028
20	0.013	44	0.071	68	0.168	92	0.028
21	0.013	45	0.071	69	0.168	93	0.028
22	0.013	46	0.071	70	0.168	94	0.028
23	0.013	47	0.071	71	0.168	95	0.028

 Table 3. Standard Project Storm for HEC-HMS Model (DS10)

9 Probable Maximum Precipitation

DS10 is a Standard 1 Dam and is required by ER 1110-8-2(FR) (USACE, 1991) to have an inflow design flood (IDF) equal to the PMF. The PMF is determined by applying the probable maximum precipitation (PMP) to the drainage area upstream of the dam.

Hydrometeorological Report 51 and 52 (HMR 51&52) were used to determine the PMP for the watershed. The MMC Precip Tool version 1.2.0 (MMC, 2017) was used to determine PMP depths and the HEC-HMS version 4.4beta model (HEC, 2020) was used to optimize the PMP event over the watershed. The MMC Precip tool is a GIS extension within ArcMap that uses a georeferenced shapefile of the watershed along with HMR 51 gridded depth-area-duration values to produce a watershed average depth-area-duration table. The HMR 51 depths are shown in Table 4.

Although the MMC Precip Tool optimizes a PMP storm following standard procedures outlined in HMR 52, HEC-HMS 4.4beta has the functionality to optimize a desired statistic. The benefit to optimizing the PMP storm in HEC-HMS is that it accounts for channels, subbasins, and reservoir routing.

The optimization trials preformed in HEC-HMS altered the PMP storm area, orientation, and center coordinates to maximize either the peak inflow, storm volume, or reservoir pool elevation. Storm peak intensity period was altered through the Meteorological Model to test sensitivity to the hyetograph pattern. Optimization initial values for all these parameters were set so they were not near the values determined by the MMC Precip tool which were initially input into the Meteorological Model. Two to three hundred iterations resulted in convergence.

Table 5 shows the results of the three optimization trials to peak inflow, storm volume, and reservoir pool elevation. Optimization trials were run, their optimized parameters determined, and then these were entered into the HMR52 meteorological model and a simulation run to check results. Additional optimization trials were completed with different initial values when convergence results were questionable.

Optimization to peak flow, storm volume, and reservoir pool elevations produced similar results. Optimization based on the maximum peak inflow was adopted.

Figure 6 shows the PMP over the watershed upstream of DS10 using optimization results from the HEC-HMS HMR52 Tool in the MMC Precip Tool interface.

Figure 7 through Figure 10 show the optimized PMP adopted for this study over the four subbasins of the watershed. Subbasin characteristics will be provided later in the report.

Table 6 compares the PMP used in this analysis with the PMP used in the Original Design of the dam (USACE, 1975).

	PMP Precipitation Depths (in)					
Basin Area (sq mi)	6 hour	12 hour	24 hour	48 hour	72 hour	
10	26	30.6	32.2	35.7	37.5	
200	19	22.5	24.3	27.5	29.1	
1000	13.9	16.9	18.6	21.8	23.5	
5000	8.4	10.8	12.8	16	17.4	
10000	6.4	8.6	10.4	13.6	15	
20000	4.5	6.7	8.3	11.3	12.7	

Table 4. HMR 51 Depth-Area-Duration Values (MMC, 2017)

Table 5. PMP Optimization Trials

			Optimization Trial Statistical Result		
Storm Parameter	Meteorological Model Initial Value*	Optimization Initial Value	(ADOPTED) Peak Flow (cfs)	Max Storm Volume (AF)	Max Pool Elevation (ft- NAVD88)
Area (sq mi)	10	25	10	10	10
Preferred Orientation (degrees)	244	244	-	-	-
Actual Orientation (degrees)	170	170	164.5	159.7	161.6
Peak Intensity Period	Hours 36-42	Hours 36-42	Hours 36-42	Hours 36-42	Hours 36-42
1 to 6 ratio	0.306	0.306	-	-	-
x-coordinate	-8942	-8942	-9230	-8937.5	-9025.1
y-coordinate	2043391	2043391	2043486	2043793	2043827
Reservoir Optimization Results					
Peak Inflow (cfs)			36,878	36,878	36,878
Peak Discharge (cfs)			0	0	0
Inflow Volume (AF)			6,092	6,092	6,092
Peak Storage (AF)			6,092	6,029	6,092
Peak Elevation (ft)			1208.5	1208.5	1208.5

*Estimate from the MMC Precip Tool. All results similar in value. Max pool elevation optimization was adopted.



Figure 6. PMP Orientation Over Watershed (MMC Precip Tool with Results from HMS

HMR 52 Storm Tool)





DS10 Thomas Creek: LP-18 Probable Maximum Precipitation **HEC-HMS Version 4.4beta HMR52 Storm** Cumulative Incremental 40 1.6 Cumulative Rainfall (in) 2 0 1 2 2 2 2 2 0 1 2 2 2 2 2 DS10 0 60 0 30 S 6 27 R) ふ Zo 5 6 く $\langle \circ \rangle$ Time in Hours

Figure 8. Subbasin LP-18 HMR 51&52 (5-minute interval)



Figure 9. Subbasin LP-19 HMR 51&52 (5-minute interval)



Figure 10. Subbasin LP-20A HMR 51&52 (5-minute interval)

	12-hour	24-hour	72-hour
1975 DM	22.45	24.86	24.86
HMR 51&52	29.9	32.9	37.2

Table 6. Comparison of PMP Depths for Various Durations

10 Hydrologic Model

Figure 11 shows the HEC-HMS version 4.4beta hydrologic model used to determine inflows into DS10. Subbasin delineations and subbasin and channel properties were adopted from the calibrated FYRA future conditions model except in the case of LP-20 which was split into LP-20A and LP-20B where LP-20A is above the dam site and LP-20B is below. The HEC-HMS version 4.4beta model was used in order to use the most up to date HMR52 Storm modeling for PMP optimization.



Figure 11. HEC-HMS Model

11 Watershed Parameters

The following sections describe the watershed parameters input into the HEC-HMS model.

11.1 Drainage Area

The full drainage area of DS10 is 4.3 square miles. The drainage area for DS10 was delineated in this study using 10-meter DEM data and found to match past delineations from the 1975 DM and the FYRA study (FYRA, 2018). However, in the case or the FYRA study area, the dam site fell within a subbasin (LP-20) and not at the outlet. For this reason, LP-20 was split into two subbasins (one above and one below the dam) and LP-20's Clark Unit Hydrograph (UH) parameters adjusted to match the 1% AEP peak flow and volume at the junction downstream of the original LP-20.

Table 7 shows the drainage areas of the subbasins used in this study.

Subbasin	Area (sq mi)
LP-17	1.54
LP-18	1.09
LP-19	1.43
LP-20A	0.3
Total	4.36

Table 7. Drainage Areas

11.2 Unit Hydrographs

Unit hydrographs were compared between the 1975 DM (USACE, 1975) and the calibrated 2018 FRYA model (FYRA, 2018). The 30-minute unit hydrographs from the 1975 DM are shown in Figure 12.

The 1975 DM unit hydrographs were developed from six events recorded at the Little Papillion at Irvington stream gauge below the confluence of Thomas Creek with Knight Creek. An existing USACE dam, Lake Cunningham, is located on Knight Creek.

The six events had peak flows ranging from 7,500 to 15,250 cfs. The unit hydrographs used for the RDF and the PMF routings were adjusted to represent future conditions and had peaking applied. Future conditions for 2020 in the 1975 DM assumed a percent impervious surface of 25 percent (USACE, 1975), which is larger than the currently estimated 17.5 percent above the dam (FYRA, 2018). The natural condition unit hydrograph estimated in the 1975 DM was peaked about 124 percent to produce the RDF unit hydrograph. The RDF unit hydrograph was then peaked an additional 150 percent for an overall peaking total of about 175 percent. This peaking pre-dates ER 1110-8-2(FR) (USACE, 1991) requirements of 125 to 150 percent unit hydrograph peaking.

The DM does not specifically note why 175 percent peaking was used in the Original Design. It could be because the watershed was expected to be fully developed by 2020, because the metropolitan area of the city of Omaha is downstream, and because the watershed (4.3 square

miles) is much smaller than the watershed at the Irvington gauge (32 square miles) where the unit hydrographs were initially developed. The original unit hydrograph was a 1-hour unit hydrograph at the Irvington gauge that was converted to a 30-minute duration in the Original Design due to the small size of the DS10 drainage area.

The 2018 FYRA unit hydrographs were determined from watershed calibration to three events ranging from 578 to 4,170 cfs at the Irvington stream gauge and verified with an additional event. Calibrations were to more current events using better data including gridded rainfall data. The FYRA report does not address why the older, larger events were not used in model calibration. Reasons may include better data for more current events and that the older events do not reflect the current development of the overall Papillion Creek watershed.

The FYRA 2018 model unit hydrographs did not originally include peaking. These were peaked in this study so that inflows were peaked 125, 150, and 175 percent at the dam.

The 30-min unit hydrographs for the FYRA 2018 study were determined in this analysis by running the model with 1 inch of rainfall over 30 minutes without watershed soil losses. This produced 30-minute unit hydrographs that could then be compared with the 30-minute unit hydrographs from the 1975 DM.

The 2018 FYRA unit hydrographs were adopted for this analysis. Figure 13 compares the 30minute unit hydrographs at the dam from USACE and FYRA and Figure 14 shows the adopted unit hydrographs. Unit hydrographs without peaking were used for the frequency events (the 0.2 AEP to 50 percent AEP). The 125-percent unit hydrograph peaking was used for the RDF to set the minimum spillway crest of the dam. The 150 and 175 percent unit hydrograph peaking were used for the dam spillway design and flowage easement; this will be addressed in more detail in a later section of the report.

Table 8 shows the Clark unit hydrograph parameters for the adopted unit hydrographs and their peak flows.

		No Unit Hydrograph Peaking				
	LP-17	LP-18	LP-19	LP-20A	At DS10	
Peak Discharge (cfs)	771	453	814	186	1,846	
Tc (hr)	0.86	0.97	0.69	0.3	-	
R (hr)	0.71	0.92	0.62	0.67	-	
Unit Hydrograph Peaking (%)	0	0	0	0	0	
		125%	Unit Hydro	ograph Peakin	g	
	LP-17	LP-18	LP-19	LP-20A	At DS10	
Peak Discharge (cfs)	1,011	603	1,052	306	2,310	
Tc (hr)	0.611	0.69	0.491	0.213	-	
R (hr)	0.505	0.654	0.441	0.263	-	
Unit Hydrograph Peaking (%)	1.31	1.33	1.29	1.65	1.25	
	150% Unit Hydrograph Peaking					
	LP-17	LP-18	LP-19	LP-20A	At DS10	
Peak Discharge (cfs)	1,237	755	1,259	341	2,771	
Tc (hr)	0.459	0.518	0.368	0.16	-	
R (hr)	0.379	0.491	0.331	0.198	-	
Unit Hydrograph Peaking (%)	1.60	1.67	1.55	1.83	1.50	
		175%	Unit Hydro	ograph Peakin	g	
	LP-17	LP-18	LP-19	LP-20A	At DS10	
Peak Discharge (cfs)	1,488	927	1,490	371	3,231	
Tc (hr)	0.335	0.377	0.268	0.117	-	
R (hr)	0.276	0.358	0.241	0.144	-	
Unit Hydrograph Peaking (%)	1.93	2.05	1.83	1.99	1.75	

 Table 8. Adopted Unit Hydrograph Peak Flows and Parameters



Figure 12. 1975 DM 30-minute Unit Hydrographs







Figure 14. Adopted 30-Minute Unit Hydrographs

11.3 Soil Losses

Soil initial and constant losses were those adopted from the 2018 FYRA model. Table 10 lists the soil losses for DS10. Percent imperviousness was also adopted from the FYRA model.

	Calibrated Existing Model Loss Rates				
	LP-17	LP-18	LP-19	LP-20A	
Initial Loss (in)	0.65	0.65	0.65	0.65	
Constant Loss (in/hr)	0.5	0.5	0.5	0.5	
Existing Condition Imperviousness (%)	1	1	1	1	
	Future Model Loss Rates				
	LP-17	LP-18	LP-19	LP-20A	
Initial Loss (in)	0.65	0.65	0.65	0.65	
Constant Loss (in/hr)	0.5	0.5	0.5	0.5	
Future Condition Imperviousness (%)	10	10	26	31	

1 able 9. Soli Losses	Table	9.	Soil	Losses
-----------------------	-------	----	------	--------

11.4 Baseflow

Baseflow was not modeled in the original FYRA model and is not modeled in this investigation for DS10.

12 Reservoir Design Flood (RDF) Routing

The RDF was used to determine the initial minimum spillway elevation for DS10. The RDF was assumed to be the SPF determined by routing the standard project storm over the watershed upstream of the dam. The unit hydrographs that peaked the combined inflow hydrograph (at the dam) by 125 percent were used in this routing. Future conditions model loss rates described in the previous section of this report were also used. The model computation time steps were 5 minutes and the precipitation for the SPF was in 1-hour increments from the Design Memorandum (DM). The lower level service outlet was operational; this agrees with the Original Design of the existing Papillion Creek Dams based on the 1970s DM documentation (USACE, 1973).

Figure 15 shows the routing of the SPF into the empty dry dam using the 125-percent peaked unit hydrograph. Note that the SPF precipitation is shown in 5-minute increments.



Figure 15. Reservoir Design Flood Routing (precipitation increment 5-minunte depths)

13 Spillway Design Flood Optimization

Spillway design flood routing included the Most Reasonable PMF (MR PMF) and the Reasonable High PMF (RH PMF) with future-condition land use. The MR PMF and the RH PMF differed in their PMP depths, soil losses and the peaking of their unit hydrographs. These differences are summarized below. A Reasonable Low PMF (RL PMF) will be determined in another phase of the project.

The adjustments to the RH PMF loss parameters and PMP depths were referenced from Garrison Dam Issue Evaluation Study (EIS) and the unit hydrograph peaking was comparable to that used in the 1975 DM Original Design.

- Most Reasonable PMF (Best Estimate)
 - \circ Soil loss rates = calibration values (0.65 in initial deficit and 0.5 in/hr infiltration)

- \circ Transform = calibrated values, unit hydrograph peaked 150%
- \circ PMP = PMP determined from HMR 51&52 optimization
- Reasonable High PMF (Reasonable Worst Case)
 - \circ Soil loss rates = -25% calibration values (0.49 in initial deficit and 0.38 in/hr infiltration)
 - \circ Transform = calibrated values, unit hydrograph peaked 175%
 - \circ PMP = base PMP with ordinates increased 5%

Both the MR and RH PMFs were routed through the dam to determine spillway and dam embankment design. Dam embankment height was determined as the highest of two options:

- 1. The RH PMF maximum pool elevation or
- 2. The MR PMF pool elevation plus three feet.

In the case of this site, the MR PMF plus three feet resulted in the highest elevation and was used to set the dam height.

Engineering Regulation 1110-8-2(FR), *Inflow Design Floods for Dams and Reservoirs* (USACE, 1991), requires two antecedent pool conditions prior to PMF routings for spillway and dam embankment design. The two antecedent pool conditions are:

- 1. PMF routed over the full flood control pool and
- 2. PMF routed over the 5-day drawdown pool.

The 5-day drawdown pool elevation was determined by routing the $\frac{1}{2}$ PMF over the full multipurpose pool with outlets operational followed by the PMF five days later with outlets blocked. The five-day spacing was determined from the peak of the $\frac{1}{2}$ PMF and the peak of the PMF following.

In the case of the 5-day drawdown pool simulations, the ½ PMF was routed with the service outlets operational while the PMF following five days later was routed with the outlets blocked. The antecedent flood event is evacuated in less than five days so the starting pool of 5-day drawdown simulation was an empty pool in the case of DS10.

The adopted dam design used the antecedent pool starting at the top of flood control; this antecedent pool produced the highest PMF pool elevation.

Eleven different spillway crest elevation and width combinations were used to help optimize the spillway and dam embankment height cut-and-fill to reduce costs at the site. Quantities were determined by the project geotechnical engineer. Only the PMF simulations with the antecedent pool starting at full flood control pool were used in this optimization. These produced the highest pools of the two antecedent conditions described previously. The 5-day drawdown scenario was then simulated for only the design with the best balance between spillway cut and embankment fill.

Table 10 shows the spillway crest and width combinations for the dam. Table 11 shows the antecedent pool and PMF combinations. Figure 16 compares the Most Reasonable and Reasonable High PMFs.

Table 12 and Table 13 show the results of the family of optimization simulations.

Simulation ID	Spillway Crest Elev (ft-NAVD88)	Spillway Width (ft)
L250	1187.6	250
L400	1187.6	400
L550	1187.6	550
M100	1189.6	100
M250	1189.6	250
M400	1189.6	400
M550	1189.6	550
H100	1191.6	100
H250	1191.6	250
H400	1191.6	400
H550	1191.6	550

 Table 10. Dam Spillway Crest Elevations and Width Combinations

Table 11. Probable Maximum Flood Combinations

Simulation ID	Description
MR	Most Reasonable PMF - 150% UH peaking
RH	Reasonable High PMF - 175% UH peaking
fc	Starting pool top of flood control
5d	Starting pool top of 5-day drawdown pool



Figure 16. PMF Comparison

	Most Reasonable Probable Maximum Flood							
Spillway Crest Elev (ft)	Spillway Width (ft)	Starting Pool (ft)	Peak Inflow (cfs)	Inflow Vol (AF)	Peak Discharge (cfs)	Peak Elevation (ft)	TOD (ft- NAVD88)	
Starting Pool a	at Top of FC							
1187.6	250	1184.6	36,878	6092	24,499	1198.8	1201.8	
1187.6	400	1184.6	36,878	6092	28,296	1197.0	1200.0	
1187.6	550	1184.6	36,878	6092	30,388	1195.8	1198.8	
1189.6	100	1184.6	36,878	6092	15,297	1203.3	1206.3	
1189.6	250	1184.6	36,878	6092	23,019	1200.4	1203.4	
1189.6	400	1184.6	36,878	6092	27,110	1198.7	1201.7	
1189.6	550	1184.6	36,878	6092	29,384	1197.7	1200.7	
1191.6	100	1184.6	36,878	6092	13,534	1204.4	1207.4	
1191.6	250	1184.6	36,878	6092	21,103	1201.8	1204.8	
1191.6	400	1184.6	36,878	6092	25,297	1200.3	1203.3	
1191.6	550	1184.6	36,878	6092	27,867	1199.4	1202.4	
Starting Pool a	nt 5-Day Drawdown							
1191.6	100	1151.0	36,878	6092	10,265	1202.5	1205.5	

Table 12. Most Reasonable PMF Spillway Optimization Results

Orange = ADM design; Green = After ADM design

Table 13. Reasonable High PMI	F Spillway Optimization Results
-------------------------------	--

Reasonable High Probable Maximum Flood							
Spillway Crest Elev (ft)	Spillway Width (ft)	Starting Pool (ft)	Peak Inflow (cfs)	Inflow Vol (AF)	Peak Discharge (cfs)	Peak Elevation (ft)	TOD (ft- NAVD88)
Starting Po	ool at Top of FC						
1187.6	250	1184.6	43,123	6727	27,954	1199.7	1199.7
1187.6	400	1184.6	43,123	6727	32,494	1197.7	1197.7
1187.6	550	1184.6	43,123	6727	34,997	1196.5	1196.5
1189.6	250	1184.6	43,123	6727	26,538	1201.3	1201.3
1189.6	400	1184.6	43,123	6727	31,262	1199.5	1199.5
1189.6	550	1184.6	43,123	6727	33,888	1198.3	1198.3
1191.6	100	1184.6	43,123	6727	15,829	1205.6	1205.6
1191.6	250	1184.6	43,123	6727	24,751	1202.8	1202.8
1191.6	400	1184.6	43,123	6727	29,627	1201.2	1201.2
1191.6	550	1184.6	43,123	6727	32,637	1200.1	1200.1
Starting Pool a	at 5-Day Drawdown						
1191.6	100	1151.0	43,123	6727	12,470	1203.8	1203.8

Orange = ADM design; Green = After ADM design

14 Dam Designs Leading to the NED Plan

This section documents the DS10 designs leading to the NED Plan. These are important because they illustrate the changes that were incorporated as the study progressed.

Figure 17 shows the ADM design. This design did not have a balance of cut and fill at the time of the ADM meeting. The highest PMF pool (1201.8 ft) of the designs considered at that time was used. However, it was determined after ADM that when cut and fill was assessed for various designs that a smaller spillway cut with higher pool and dam was more economical.

Figure 18 shows the After ADM design. This design was used because it had the best balance of spillway cut and embankment fill at the site. The biggest change in the design was the decrease in the spillway width from 250 to 100 ft.

Figure 19 and Figure 20 show the spillway design flood routings for the After ADM Design for the Reasonable High PMF. Required starting pool elevations were the top of flood control and the 5-day drawdown pool as required by ER 1110-8-2(FR). In the case of the 5-day drawdown pool simulations, the $\frac{1}{2}$ PMF was routed with the service outlets operational; the PMF following five days later was routed with the outlets blocked. The antecedent flood event is evacuated in less than five days so the starting pool of 5-day drawdown simulation for the PMF was an empty pool.

The combination of the Most Reasonable PMF with the antecedent pool set to the top of flood control was used to inform the top of dam elevation. Three feet of freeboard with the Most Reasonable PMF was assumed to set the top of dam elevations. The Reasonable High PMF pool was used to determine the Real Estate flowage easement.



Refer to Section 18 for information on the selected design.

Figure 17. Dry Dam Design (ADM Design)



Figure 18. Dry Dam Design (After ADM Design)

Table 14.	Pertinent	Information	(Preci	pitation)
			`	

Precipitation (in)				
Reasonable High Probable Maximum Precipitation (RH PMP) - 1.05*MR PMP				
72-hour total depth (in)	39.1			
1-hour max depth (in)	15.3			
5-min max depth (in)	1.68			
Most Reasonable Probable Maximum Precipitation (MR PMP)				
72-hour total depth (in)	37.2			
1-hour max depth (in)	14.6			
5-min max depth (in)	1.6			
Reservoir Design Flood Precipitation - SPS (Dry Dam Design)				
96-hour total depth (in)	15.81			
1-hour maximum depth (in)	3.75			
5-min max depth (in)	0.31			

Design Event	S	
	ADM Design (Dry	After ADM (Dry
	Dam)	Dam)
Spillway Design Flood - RH PMF		
Peak inflow (cfs)	43,100	43,100
Peak outflow (cfs)	28,000	15,800
Inflow volume (AF)	6727	6727
Spillway Design Flood - MR PMF		
Peak inflow (cfs)	36,900	36,900
Peak outflow (cfs)	24,500	13,500
Inflow volume (AF)	6092	6092
Reservoir Design Flood		
Peak inflow (cfs)	7,490	7,490
Peak outflow (cfs)	1,480	1,480
Inflow volume (AF)	1944	1944
Elevations (ft-NA)	/D88)	
	ADM Design (Dry	After ADM (Dry
	Dam)	Dam)
Top of Dam	1201.8	1207.4
RH PMF Pool	1199.7	1205.6
MR PMF Pool	1198.8	1204.4
Spillway Crest	1187.6	1191.6
Top of Flood Control Pool	1184.6	1184.6
Top of Multipurpose Pool	-	-
Outlet Invert Elevation	1151.0	1151.0
Min Pool Elevation	1151.0	1151.0
Storage (AF)		
	ADM Design (Dry	After ADM (Dry
	Dam)	Dam)
Top of Dam	4111	5726
RH PMF Pool	3587	5172
MR PMF Pool	3376	4821
Spillway Crest	1415	1992
Top of Flood Control Pool	1055	1055
Top of Multipurpose Pool	0	0
Outlet Invert Elevation	0	0

 Table 15. Design Pertinent Information (ADM & After ADM Designs)



Figure 19. After ADM Design - Starting Pool Top of Flood Control



Figure 20. After ADM Design - Starting Pool 5-Day Drawdown

15 Hypothetical Design Storm Modeling

Two hypothetical scenarios were modeled:

- 1. Dry dam future conditions
- 2. Dry dam existing conditions

The hypothetical design storms were routed into an empty reservoir because the dam has no permanent pool. Hypothetical or frequency events included the 0.2-, 0.5-, 1-, 2-, 4-, 10-, 20-, 50- and 99.9-percent AEP events (500-, 200-, 100-, 50-, 25-, 10-, 5- and 2- year events). Results shown are for existing and future conditions. Both sets of hydrographs were provided to the Omaha District Hydraulics section.

The hypothetical precipitation were NOAA Atlas 14 12-hour depths with temporal patterns and areal reductions from the Applied Weather Associates (AWA) study documented in Appendix J of the FYRA 2018 (FYRA, 2018). Temporal pattern calculations are shown in Appendix H of the FYRA report. These are the same events used in the project before TSP.

Table 16 shows the 12-hour NOAA Atlas 14 precipitation depths used for the frequency events. Appendix A-1B shows temporal patterns for those events not determined by FYRA. The FYRA report shows the other temporal events.

Table 17 and Table 18 and Figure 21 and Figure 22 summarize the outflows from the dry dam for these nine events with existing and future conditions. The unit hydrograph without peaking was used.

Note that a 70 square mile storm area was used in the analysis for cost-benefit calculations instead of the 10 square mile storm area. This was a decision made by the Omaha District Hydraulics section. The flows out of DS10 were used to design the proposed Little Papillion Creek levee which had a drainage area of about 70 square miles.

			NOA	AA Atlas 1	4 Precip	itation D	epth				
	99.9%	9.9% 50% 20% 10% 4% 2% 1% 0.5% 0.2%									
Duration	AEP	AEP	AEP	AEP	AEP	AEP	AEP	AEP	AEP		
12-hr	1.88	2.64	3.33	3.96	4.94	5.77	6.67	7.65	9.06		

 Table 16. NOAA Atlas 14 12-hour Depths

Event (AEP%)	Return Period (YR)	Peak Inflow (cfs)	Peak Outflow (cfs)	Starting Pool Elevation (ft)	Peak Elevation (ft)	Rise in Pool (ft)
0.2	500	6,145	1,397	1151	1181.3	30.3
0.5	200	4,953	1,330	1151	1178.8	27.8
1	100	4,139	1,276	1151	1176.9	25.9
2	50	3,390	1,215	1151	1174.8	23.8
4	25	2,696	1,145	1151	1172.5	21.5
10	10	1,893	1,043	1151	1169.5	18.5
20	5	1,391	952	1151	1167	16
50	2	851	790	1151	1163.1	12.1
99.9	1	294	293	1151	1155.9	4.9

Table 17. Existing Conditions Frequency Events

 Table 18. Future Conditions Frequency Events

Event (AEP%)	Return Period (YR)	Peak Inflow (cfs)	Peak Outflow (cfs)	Starting Pool Elevation (ft)	Peak Elevation (ft)	Rise in Pool (ft)
0.2	500	6,371	1,414	1151	1182	31
0.5	200	5,175	1,349	1151	1179.5	28.5
1	100	4,361	1,297	1151	1177.6	26.6
2	50	3,611	1,240	1151	1175.6	24.6
4	25	2,924	1,175	1151	1173.5	22.5
10	10	2,110	1,078	1151	1170.5	19.5
20	5	1,600	997	1151	1168.2	17.2
50	2	1,063	876	1151	1165.1	14.1
99.9	1	494	491	1151	1157.9	6.9



Figure 21. Existing Conditions Frequency Event Outflows and Pool Elevations



Figure 22. Future Conditions Frequency Event Outflows and Pool Elevations

16 Cost Optimization

Cost optimization was undertaken to determine if DS10 could produce the same benefits of the current design (NED Plan) at a lower cost. The additional costs of the lining and excavation of the spillway resulted in higher costs than the design with the spillway crest at the top of the RDF.

In this analysis, the spillway was excavated to the 275-year level of protection for a 70-square mile rainfall event and lined to help protect the spillway from more frequent flows. In comparison, the original level of protect was the RDF, an event larger than the 0.2 percent AEP (~500-year event). The level of protection is the return period of the event that produces spillway flow. Note that the 275-year event was used opposed to the 500-year event to avoid running an additional benefit analysis which would affect schedule and study costs.

The spillway crest was lowered to the peak pool of the 275-year 70-square mile event over the drainage area behind the dam. Again, this was the equivalent to the 500-year 70-square mile rainfall event used in the analysis of alternatives downstream. Rainfall intensities increase with smaller drainage areas in accepted guidance.

Figure 23 shows this scenario. A dam with this level of protection has the following:

- Top of dam = 1200.7 ft NAVD88
- Spillway crest = 1182.0 ft NAVD88
- Spillway width = 100 ft
- Flowage easement pool or RH PMF pool = 1198.7 NAVD88



Figure 23. Decreased Level of Protection Scenario

17 Study Risks

Identified study risks related to modeling of DS10 outlined below.

17.1 Model Calibration Events

The Papillion Creek watershed does not have a long history of gauge data to which to calibrate the model. The three events used to calibrate the FYRA model were all recent events and all occurred in the month of June. In comparison, the 1975 DM (USACE, 1975) estimated the unit hydrograph for the site from six events at the Irvington stream gauge downstream that were much larger than those used in the FYRA calibration.

This is a minor to moderate risk. It could lead to parameter adjustment in the model as the watershed experiences historic events in the future.

This risk was mitigated by incorporating additional unit hydrograph peaking in the RH PMF analysis used to determine the maximum pool that also informed the flowage easement.

17.2 Dry Dam Storage Loss Due to Sedimentation

While the dry dam culvert design is expected to efficiently pass sediment, no analysis was conducted to determine expected sedimentation and future storage loss impacts to flood risk reduction.

This is a minor to moderate risk. It could be mitigated with additional reservoir sedimentation study.

17.3 Dam Safety Risk Analysis

The feasibility analysis to date has included very limited dam safety risk analysis and has not compared risk across alternatives.

This is a moderate risk. However, risk analysis is planned in next steps to mitigate this risk.

18 NED Design

Figure 24 shows the design of DS19 adopted as the NED after optimization and incorporating input from other disciplines. The conduit outlet invert was raised from 1151.0 ft to 1154.0 ft NAVD88 to elevate the outlet into more stable geology (glacial till). This change increased the top of flood control pool (determined by the RDF) by 0.4 feet, but it did not produce a perceptible increase in the PMF pool elevations. Results developed up to this point in the study using the After ADM Dry Dam Design were not negatively impacted by this change. See Appendix A-1A of this document for more information on sensitivity testing.

The RDF was not modified but retained as the SPF as was the case in previous designs. This is the event used to determine flood control pools for the existing Papillion Creek Dams as well.

Figure 25 and Table 19 show the outlet rating curve used for this design. Capacity and spillway curves remain the same as documented previously.

Figure 26 shows the spillway design flood routing and Figure 27 shows the RDF routing.



Figure 24. NED Design



Figure 25. NED Outlet Rating Curve

Elevatio n (ft		Elevatio n (ft		Elevatio n (ft		Elevatio n (ft	
NAVD88	Discharg	NAVD88	Discharg	NAVD88	Discharg	NAVD88	Discharg
)	e (cfs)						
1154.0	0.0	1167.0	831.1	1180.0	1279.0	1193.0	1606.6
1154.5	9.6	1167.5	852.7	1180.5	1293.1	1193.5	1617.8
1155.0	27.2	1168.0	873.7	1181.0	1307.1	1194.0	1629.0
1155.5	50.0	1168.5	894.3	1181.5	1321.0	1194.5	1640.1
1156.0	77.0	1169.0	914.4	1182.0	1334.6	1195.0	1651.2
1156.5	107.7	1169.5	934.1	1182.5	1348.2	1195.5	1662.2
1157.0	141.5	1170.0	953.3	1183.0	1361.6	1196.0	1673.1
1157.5	178.3	1170.5	972.2	1183.5	1374.9	1196.5	1683.9
1158.0	217.9	1171.0	990.7	1184.0	1388.1	1197.0	1694.7
1158.5	260.0	1171.5	1008.9	1184.5	1401.1	1197.5	1705.3
1159.0	304.5	1172.0	1026.8	1185.0	1414.0	1198.0	1716.0
1159.5	351.3	1172.5	1044.3	1185.5	1426.8	1198.5	1726.5
1160.0	400.3	1173.0	1061.6	1186.0	1439.5	1199.0	1737.0
1160.5	451.4	1173.5	1078.6	1186.5	1452.0	1199.5	1747.5
1161.0	504.4	1174.0	1095.3	1187.0	1464.5	1200.0	1757.8
1161.5	539.3	1174.5	1111.7	1187.5	1476.9	1200.5	1768.1
1162.0	572.0	1175.0	1128.0	1188.0	1489.1	1201.0	1778.4
1162.5	602.9	1175.5	1144.0	1188.5	1501.3	1201.5	1788.6
1163.0	632.4	1176.0	1159.8	1189.0	1513.3	1202.0	1798.7
1163.5	660.5	1176.5	1175.3	1189.5	1525.3	1202.5	1808.8
1164.0	687.4	1177.0	1190.7	1190.0	1537.2	1203.0	1818.8
1164.5	713.4	1177.5	1205.9	1190.5	1549.0	1203.5	1828.8
1165.0	738.4	1178.0	1220.8	1191.0	1560.6	1204.0	1838.7
1165.5	762.7	1178.5	1235.6	1191.5	1572.3	1204.5	1848.5
1166.0	786.1	1179.0	1250.3	1192.0	1583.8		
1166.5	808.9	1179.5	1264.7	1192.5	1595.2		

Table 19. NED Outlet Rating Curve



Figure 26. NED Spillway Design Flood -- PMF Routed Over Full Flood Control Pool

(Outlet Blocked)



Figure 27. NED Reservoir Design Flood -- SPF Routed Over Full Multipurpose Pool (Outlet Functional)

19 Equivalent Period of Record

Based on reference to Table 4-5 in EM 1110-2-1619, the equivalent years of record for a rainfallrunoff model calibrated to several events recorded at a short-interval gauge in the watershed is somewhere between 20-30 years.

The recommended equivalent years of record for the Papillion Creek GRR project is 23 years. Several locations were used in the calibration of the model, but the events used were small in comparison with the historic and moderate events of record (except in the Papillion Creek at Fort Crook location). However, the watershed has changed significantly since these historic events (like the 1964 flood) so calibration to these larger events would not reflect current conditions.

In addition, the model was calibrated to events and not peak flow frequencies. Calibration or verification to a peak flow frequency at a gauge would have decreased uncertainty in model

results and resulted in a longer equivalent record. Twenty-three years opposed to 20 was selected to include the higher confidence due to the availability of higher-quality calibration data like radar rainfall.

The estimate of 23 year of equivalent years of record was used for both the existing and future conditions. Future conditions (2040) are not that far in the future so an assumption of 23 years (the same uncertainty in data) was considered reasonable.

20 References

FYRA. 2018. Papillion Creek Watershed Hydrologic Analysis. Final Submittal. Prepared for the Papio-Missouri Natural Resources District. October 2018.

HEC. 2020. HEC-HMS version 4.4beta. February 2020.

MMC. 2017. MMC Precip Tool v1.2.0. Modeling Mapping and Consequence Center. March 2017.

USACE. 1991. ER 1110-8-2(FR). Inflow Design Floods for Dams and Reservoirs. U.S. Army Corps of Engineers. March 1991.

USACE. 1975. Papillion Creek and Tributaries Lakes Nebraska. Specific Design Memorandum No. MPC-33 Site 10. Army Engineering District, Omaha. Corps of Engineers Omaha, Nebraska. May 1975.

USACE. 1973. Papillion Creek and Tributaries lakes Design Memorandum No. MPC-22 Preliminary Development & Site Selection. U.S. Army Engineer District Omaha, Nebraska. February 1973.

USACE. 1971. Papillion Creek and Tributaries Nebraska General Design Memorandum No. MPC-10. U.S. Army Corps of Engineers Omaha District. August 1971.

WEST, 2013. Sedimentation Conditions at the Papio Creek Projects Updated August 2013. M.R.B. Sediment Memorandum 19a.

Appendix A-1A. Increase in Outlet Invert

Increase in Outlet Invert

This appendix summarized impacts to the results after the outlet invert of the dam was raised three feet from 1151.0 ft to 1154.0 ft NAVD88. Results presented previously were largely not sensitive to this change or their change would not negatively impact the benefit cost ratio results for the project. Figure A1 shows the conceptual design of the dry dam after the outlet invert of the box culvert is raised three feet.

Results that differed from those presented in this Addendum included:

- A 0.4-foot increase in the flood control pool (from 1184.6 ft to 1185.0 ft NAVD88). This increased the starting pool of the inflow design flood, but this did not affect the top of dam or flowage easement elevations. The updated PMF routing results are shown in Figure A2.
- A decrease in peak outflows for the frequency events (0.2 to 50 percent annual exceedance probabilities (AEP)) from 70 to 90 cfs. This increases the benefits of the project and would not negatively affect the benefit cost ratio. Table A1 shows the updated results.
- An increase in the peak pool elevations created by the frequency events. These changed from 1 foot for the 50 percent AEP to 0.3 of a foot for the 0.2 percent AEP. These increases would not affect the benefit cost ratio because real estate acquisitions are not dependent on these changes. Table A1 shows the updated results.



Figure A1. DS10 NED Plan with Raised Outlet



Figure A2. After ADM Design – Starting Pool Top of Flood Control (Outlet Raised)

				Starting	Peak		Change in Flow	
		Peak	Peak	Pool	Elevation	Rise in	with	Change in
Event	Event	Inflow	Outflow	Elevation	(ft-	Pool	Raise	Elev with
(AEP%)	(YR)	(cfs)	(cfs)	(ft)	NAVD88)	(ft)	(cfs)	Raise (ft)
0.2	500	6371	1343	1154	1182.3	28.3	71	0.3
0.5	200	5175	1276	1154	1179.9	25.9	73	0.4
1	100	4361	1221	1154	1178	24	76	0.4
2	50	3611	1162	1154	1176.1	22.1	78	0.5
4	25	2924	1096	1154	1174	20	79	0.5
10	10	2110	994	1154	1171.1	17.1	84	0.6
20	5	1600	912	1154	1168.9	14.9	85	0.7
50	2	1063	790	1154	1166.1	12.1	86	1

Table A1. Frequency Event Results with Raised Outlet

Appendix A1-B. Rainfall Hyetographs

				1	-Year Local	Storm							
12 Hour Rainfall Dept	th (in)	1.88	Atlas 14, 2	Year (low	er bound o	f 90% confi	idence limi	it)					
Storm Size (sq mi)		10	20	30	50	70	95	120	150	200	250	300	400
ARF %		98	96.1	94.4	91.1	88.4	85	82.4	79.4	75.6	72.8	70.7	68
Rainfall Depth (in)		1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
Storm Time (hours)	Cumulative %												
0	0	0	0	0	0	0	0	0	0	0	0	0	0
0.17	0.1	0	0	0	0	0	0	0	0	0	0	0	0
0.33	0.2	0	0	0	0	0	0	0	0	0	0	0	0
0.50	0.4	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.67	0.6	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.83	0.8	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
1.00	1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.01	0.01
1.1/	1.3	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
1.33	1.5	0.03	0.03	0.03	0.03	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
1.50	1.7	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.02	0.02	0.02	0.02
1.6/	1.9	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.02
1.83	2.2	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03	0.03	0.03	0.03	0.03
2.00	2.0	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03
2.17	3.1	0.00	0.00	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04
2.55	3.0	0.07	0.07	0.00	0.00	0.00	0.00	0.00	0.05	0.03	0.03	0.03	0.05
2.50	4.Z	0.08	0.08	0.07	0.07	0.07	0.07	0.07	0.00	0.00	0.00	0.00	0.05
2.07	6	0.05	0.05	0.05	0.05	0.00	0.00	0.00	0.07	0.07	0.07	0.07	0.00
3.00	75	0.11	0.11	0.11	0.1	0.1	0.1	0.09	0.03	0.09	0.08	0.08	0.08
3.00	9	0.14	0.14	0.15	0.15	0.12	0.12	0.12	0.11	0.11	0.12	0.1	0.12
3 33	10.5	0.19	0.10	0.10	0.13	0.13	0.14	0.14	0.15	0.15	0.12	0.12	0.12
3 50	12.5	0.23	0.23	0.23	0.20	0.21	0.2	0.19	0.19	0.18	0.17	0.17	0.16
3.67	14.5	0.27	0.26	0.26	0.25	0.24	0.23	0.22	0.22	0.20	0.2	0.19	0.19
3.83	17	0.31	0.31	0.3	0.29	0.28	0.27	0.26	0.25	0.24	0.23	0.23	0.22
4.00	19.5	0.36	0.35	0.35	0.33	0.32	0.31	0.3	0.29	0.28	0.27	0.26	0.25
4.17	22.5	0.41	0.41	0.4	0.38	0.37	0.36	0.35	0.34	0.32	0.31	0.3	0.29
4.33	25.5	0.47	0.46	0.45	0.44	0.42	0.41	0.4	0.38	0.36	0.35	0.34	0.33
4.50	29.5	0.54	0.53	0.52	0.5	0.49	0.47	0.46	0.44	0.42	0.4	0.39	0.38
4.67	33.5	0.62	0.61	0.59	0.57	0.56	0.54	0.52	0.5	0.48	0.46	0.45	0.43
4.83	38.5	0.71	0.7	0.68	0.66	0.64	0.62	0.6	0.57	0.55	0.53	0.51	0.49
5.00	43.5	0.8	0.79	0.77	0.74	0.72	0.7	0.67	0.65	0.62	0.6	0.58	0.56
5.17	49.5	0.91	0.9	0.88	0.85	0.82	0.79	0.77	0.74	0.7	0.68	0.66	0.63
5.33	55.5	1.02	1	0.98	0.95	0.92	0.89	0.86	0.83	0.79	0.76	0.74	0.71
5.50	62.5	1.15	1.13	1.11	1.07	1.04	1	0.97	0.93	0.89	0.86	0.83	0.8
5.67	70.5	1.3	1.28	1.25	1.21	1.17	1.13	1.09	1.05	1	0.97	0.94	0.9
5.83	77.5	1.43	1.4	1.37	1.33	1.29	1.24	1.2	1.15	1.1	1.06	1.03	0.99
6.00	83.5	1.54	1.51	1.48	1.43	1.39	1.34	1.29	1.24	1.19	1.14	1.11	1.07
6.17	88.5	1.63	1.6	1.57	1.51	1.47	1.42	1.37	1.32	1.26	1.21	1.18	1.13
6.33	91.5	1.68	1.66	1.62	1.56	1.52	1.46	1.42	1.36	1.3	1.25	1.22	1.17
6.50	93.5	1.72	1.69	1.65	1.6	1.55	1.5	1.45	1.39	1.33	1.28	1.24	1.2
6.67	94.5	1.74	1.71	1.67	1.62	1.57	1.51	1.46	1.41	1.34	1.29	1.26	1.21
6.83	95.5	1.76	1.73	1.69	1.63	1.59	1.53	1.48	1.42	1.36	1.31	1.27	1.22
7.00	96.3	1.77	1.74	1.7	1.65	1.6	1.54	1.49	1.43	1.37	1.32	1.28	1.23
7.17	97	1.78	1.76	1.72	1.66	1.61	1.55	1.5	1.45	1.38	1.33	1.29	1.24
7.33	97.5	1.79	1.76	1.73	1.67	1.62	1.56	1.51	1.45	1.38	1.34	1.3	1.25
7.50	97.9	1.8	1.77	1.73	1.67	1.63	1.57	1.52	1.46	1.39	1.34	1.3	1.25
7.67	98.2	1.81	1.78	1.74	1.68	1.63	1.57	1.52	1.46	1.39	1.35	1.31	1.26
7.83	98.5	1.81	1.78	1.74	1.68	1.64	1.58	1.53	1.47	1.4	1.35	1.31	1.26
8.00	98.7	1.82	1.79	1.75	1.69	1.64	1.58	1.53	1.4/	1.4	1.35	1.31	1.26
8.17	98.9	1.82	1.79	1.75	1.69	1.64	1.58	1.53	1.4/	1.4	1.35	1.32	1.27
8.33	99	1.82	1.79	1.75	1.69	1.64	1.58	1.53	1.48	1.41	1.36	1.32	1.27
8.5U 0.67	99.1	1.82	1.79	1.75	1.69	1.65	1.59	1.54	1.48	1.41	1.30	1.32	1.2/
0.0/	53.2 00 0	1.63	1.0	1.70	1./	1.05	1 59	1.54	1.48	1.41	1.30	1.52	1.2/
9.00	99.5	1.03	1.0	1.70	1.7	1.05	1.39	1.34	1.40	1.41	1.30	1.32	1.27
9.17	00.5	1.03	1.0	1.70	1.7	1.05	1.55	1.54	1.40	1.41	1.30	1.32	1.27
9.33	99.6	1.83	1.0	1.70	1.7	1.05	1.55	1.54	1.40	1.41	1.30	1.32	1.27
9.50	99.7	1.03	1.0	1.76	1.7	1.65	1.55	1.54	1.40	1.41	1.30	1.32	1.27
9.67	99.8	1.03	1.0	1.70	1 71	1.66	1.0	1.55	1.45	1.42	1.37	1.33	1.20
9.83	99.9	1.84	1.01	1.77	1 71	1.66	1.0	1.55	1 49	1 42	1 37	1 33	1.20
10.00	100	1.84	1.81	1 77	1 71	1.66	1.6	1.55	1 49	1 42	1 37	1 33	1 28
10.00	100	1.84	1.01	1.77	1.71	1.66	1.0	1.55	1.45	1.42	1.37	1.33	1.20
10.33	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
10.50	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
10.67	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
10.83	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
11.00	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
11.17	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
11.33	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
11.50	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
11.67	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
11.83	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28
12.00	100	1.84	1.81	1.77	1.71	1.66	1.6	1.55	1.49	1.42	1.37	1.33	1.28

				2-	Year Local	Storm							
12 Hour Rainfall Dept	th (in)	2.64	Atlas 14, 2	Year									
Storm Size (sq mi)		10	20	30	50	70	95	120	150	200	250	300	400
ARF %		98	96.1	94.4	91.1	88.4	85	82.4	79.4	75.6	72.8	70.7	68
Rainfall Depth (in)		2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
Storm Time (hours)	Cumulative %												
0	0	0	0	0	0	0	0	0	0	0	0	0	0
0.17	0.1	0	0	0	0	0	0	0	0	0	0	0	0
0.33	0.2	0.01	0.01	0	0	0	0	0	0	0	0	0	0
0.50	0.4	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.50	0.4	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.07	0.0	0.02	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.85	0.8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01
1.00	1	0.03	0.03	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
1.1/	1.3	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.02	0.02	0.02
1.33	1.5	0.04	0.04	0.04	0.04	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
1.50	1.7	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03	0.03	0.03
1.67	1.9	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03
1.83	2.2	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04
2.00	2.6	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.05
2.17	3.1	0.08	0.08	0.08	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06
2.33	3.6	0.09	0.09	0.09	0.09	0.08	0.08	0.08	0.08	0.07	0.07	0.07	0.06
2.50	4.2	0.11	0.11	0.1	0.1	0.1	0.09	0.09	0.09	0.08	0.08	0.08	0.08
2.67	5	0.13	0.13	0.12	0.12	0.12	0.11	0.11	0.11	0.1	0.1	0.09	0.09
2.83	6	0.16	0.15	0.15	0.14	0.14	0.13	0.13	0.13	0.12	0.12	0.11	0.11
3.00	7.5	0.19	0.19	0.19	0.18	0.17	0.17	0.16	0.16	0.15	0.14	0.14	0.14
3.17	9	0.23	0.23	0.22	0.22	0.21	0.2	0.2	0.19	0.18	0.17	0.17	0.16
3.33	10.5	0.27	0.27	0.26	0.25	0.24	0.24	0.23	0.22	0.21	0.2	0.2	0.19
3.50	12.5	0.32	0.32	0.31	0.3	0.29	0.28	0.27	0.26	0.25	0.24	0.23	0.23
3.67	14.5	0.38	0.37	0.36	0.35	0.34	0.32	0.32	0.3	0.29	0.28	0.27	0.26
3.83	17	0.44	0.43	0.42	0.41	0.4	0.38	0.37	0.36	0.34	0.33	0.32	0.31
4.00	19.5	0.51	0.5	0.49	0.47	0.45	0.44	0.43	0.41	0.39	0.37	0.36	0.35
4.17	22.5	0.58	0.57	0.56	0.54	0.52	0.5	0.49	0.47	0.45	0.43	0.42	0.41
4.33	25.5	0.66	0.65	0.63	0.61	0.59	0.57	0.56	0.54	0.51	0.49	0.48	0.46
4.50	29.5	0.76	0.75	0.73	0.71	0.69	0.66	0.64	0.62	0.59	0.57	0.55	0.53
4.67	33.5	0.87	0.85	0.83	0.81	0.78	0.75	0.73	0.7	0.67	0.64	0.63	0.6
4.83	38.5	1	0.98	0.96	0.93	0.9	0.86	0.84	0.81	0.77	0.74	0.72	0.69
5.00	43.5	1 13	11	1.08	1.05	1.01	0.97	0.95	0.91	0.87	0.84	0.81	0.78
5.00	49.5	1 28	1 26	1 23	1 19	1 15	1 11	1.08	1.04	0.07	0.95	0.93	0.70
5.33	55 5	1.20	1 41	1 38	1.15	1.15	1 24	1.00	1.04	1 11	1.07	1.04	0.05
5.55	62.5	1.44	1 50	1.50	1.54	1.25	1.24	1.21	1 21	1.11	1.07	1.04	1 12
5.50	70 5	1.02	1.35	1.30	1.51	1.40	1 50	1.50	1.51	1.23	1.2	1.17	1.13
5.07	70.5	2.03	1.75	1.70	1.7	1.04	1.30	1.54	1.40	1.41	1.55	1.52	1.2/
5.65	//.5	2.01	1.97	1.95	1.67	1.01	1.74	1.09	1.05	1.55	1.49	1.45	1.4
6.00	83.5	2.16	2.12	2.08	2.01	1.95	1.87	1.82	1.75	1.6/	1.6	1.50	1.5
6.17	88.5	2.29	2.25	2.2	2.13	2.06	1.98	1.93	1.86	1.77	1.7	1.65	1.59
6.33	91.5	2.37	2.32	2.28	2.21	2.13	2.05	1.99	1.92	1.83	1.76	1.71	1.65
6.50	93.5	2.42	2.37	2.33	2.25	2.18	2.09	2.04	1.96	1.87	1.8	1.75	1.68
6.67	94.5	2.45	2.4	2.35	2.28	2.2	2.12	2.06	1.98	1.89	1.81	1.77	1.7
6.83	95.5	2.47	2.43	2.38	2.3	2.23	2.14	2.08	2.01	1.91	1.83	1.79	1.72
7.00	96.3	2.49	2.45	2.4	2.32	2.24	2.16	2.1	2.02	1.93	1.85	1.8	1.73
7.17	97	2.51	2.46	2.42	2.34	2.26	2.17	2.11	2.04	1.94	1.86	1.81	1.75
7.33	97.5	2.53	2.48	2.43	2.35	2.27	2.18	2.13	2.05	1.95	1.87	1.82	1.76
7.50	97.9	2.54	2.49	2.44	2.36	2.28	2.19	2.13	2.06	1.96	1.88	1.83	1.76
7.67	98.2	2.54	2.49	2.45	2.37	2.29	2.2	2.14	2.06	1.96	1.89	1.84	1.77
7.83	98.5	2.55	2.5	2.45	2.37	2.3	2.21	2.15	2.07	1.97	1.89	1.84	1.77
8.00	98.7	2.56	2.51	2.46	2.38	2.3	2.21	2.15	2.07	1.97	1.9	1.85	1.78
8.17	98.9	2.56	2.51	2.46	2.38	2.3	2.22	2.16	2.08	1.98	1.9	1.85	1.78
8.33	99	2.56	2.51	2.47	2.39	2.31	2.22	2.16	2.08	1.98	1.9	1.85	1.78
8.50	99.1	2.57	2.52	2.47	2.39	2.31	2.22	2.16	2.08	1.98	1.9	1.85	1.78
8.67	99.2	2.57	2.52	2.47	2.39	2.31	2.22	2.16	2.08	1.98	1.9	1.86	1.79
8.83	99.3	2.57	2.52	2.47	2.39	2.31	2.22	2.16	2.09	1.99	1.91	1.86	1.79
9.00	99.4	2.57	2.52	2.48	2.4	2.32	2.23	2.17	2.09	1.99	1.91	1.86	1.79
9.17	99.5	2.58	2.53	2.48	2.4	2.32	2.23	2.17	2.09	1.99	1.91	1.86	1.79
9.33	99.6	2.58	2.53	2.48	2.4	2.32	2.23	2.17	2.09	1.99	1.91	1.86	1.79
9.50	99.7	2.58	2.53	2.48	2.4	2.32	2.23	2.17	2.09	1.99	1.91	1.86	1.79
9.67	99.8	2.58	2.53	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
9.83	99.9	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
10.00	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
10.17	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
10.33	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
10.50	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
10.67	100	2.55	2.54	2.1.5	2.11	2.33	2 24	2.10	2.1	2	1 97	1.87	1.0
10.83	100	2.39	2.34	2.49	2.41	2.33	2.24	2.10	2.1	2	1.92	1.07	1.0
11.00	100	2.39	2.34	2.49	2.41	2.33	2.24	2.10	2.1	2	1.52	1.07	1.0
11.00	100	2.39	2.54	2.49	2.41	2.33	2.24	2.10	2.1	2	1.52	1.07	1.0
11.22	100	2.39	2.34	2.49	2.41	2.00	2.24	2.10	2.1	2	1.52	1.07	1.0
11.55	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.8/	1.8
11.50	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.8/	1.8
11.0/	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.8/	1.8
11.83	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8
12.00	100	2.59	2.54	2.49	2.41	2.33	2.24	2.18	2.1	2	1.92	1.87	1.8

				5-	Year Local	Storm							
12 Hour Rainfall Dept	th (in)	3.33	Atlas 14, 5	Year									
Storm Size (sq mi)		10	20	30	50	70	95	120	150	200	250	300	400
ARF %		98	96.1	94.4	91.1	88.4	85	82.4	79.4	75.6	72.8	70.7	68
Rainfall Depth (in)		3.26	3.2	3.14	3.03	2.94	2.83	2.74	2.64	2.52	2.42	2.35	2.26
Storm Time (hours)	Cumulative %												
0	0	0	0	0	0	0	0	0	0	0	0	0	0
0.17	0.1	0	0	0	0	0	0	0	0	0	0	0	0
0.33	0.2	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0	0	0
0.50	0.4	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.67	0.6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.01
0.83	0.8	0.03	0.03	0.03	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
1.00	12	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.02	0.02	0.02
1.17	1.3	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03	0.03	0.03	0.03
1.33	1.5	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03
1.50	1.7	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04
1.07	1.9	0.00	0.06	0.00	0.00	0.06	0.05	0.05	0.05	0.05	0.05	0.04	0.04
2.00	2.2	0.07	0.07	0.07	0.07	0.00	0.00	0.00	0.00	0.00	0.05	0.05	0.05
2.00	2.0	0.08	0.08	0.08	0.08	0.00	0.07	0.07	0.07	0.07	0.00	0.00	0.00
2.17	3.6	0.1	0.1	0.1	0.09	0.05	0.09	0.08	0.08	0.08	0.08	0.07	0.07
2.55	3.0	0.12	0.12	0.11	0.11	0.11	0.1	0.1	0.1	0.05	0.09	0.08	0.00
2.30	4.2	0.14	0.15	0.15	0.13	0.12	0.12	0.12	0.11	0.11	0.1	0.1	0.05
2.07	6	0.10	0.10	0.10	0.13	0.15	0.14	0.14	0.15	0.15	0.12	0.12	0.11
3.00	75	0.2	0.15	0.15	0.10	0.10	0.17	0.10	0.10	0.15	0.15	0.14	0.14
3.17	9	0.24	0.24	0.24	0.23	0.22	0.21	0.21	0.2	0.15	0.10	0.10	0.17
3 33	10.5	0.25	0.23	0.20	0.27	0.20	0.23	0.25	0.24	0.25	0.22	0.21	0.2
3.50	12.5	0.31	0.0	0.39	0.32	0.32	0.35	0.25	0.20	0.20	0.25	0.29	0.28
3.67	14.5	0.41	0.4	0.35	0.30	0.37	0.33	0.54	0.35	0.32	0.5	0.25	0.20
3.83	17	0.55	0.54	0.53	0.52	0.5	0.48	0.47	0.45	0.43	0.41	0.4	0.38
4.00	19.5	0.64	0.62	0.61	0.59	0.57	0.55	0.53	0.51	0.49	0.47	0.46	0.44
4.17	22.5	0.73	0.72	0.71	0.68	0.66	0.64	0.62	0.59	0.57	0.54	0.53	0.51
4.33	25.5	0.83	0.82	0.8	0.77	0.75	0.72	0.7	0.67	0.64	0.62	0.6	0.58
4.50	29.5	0.96	0.94	0.93	0.89	0.87	0.83	0.81	0.78	0.74	0.71	0.69	0.67
4.67	33.5	1.09	1.07	1.05	1.02	0.98	0.95	0.92	0.88	0.84	0.81	0.79	0.76
4.83	38.5	1.26	1.23	1.21	1.17	1.13	1.09	1.05	1.02	0.97	0.93	0.9	0.87
5.00	43.5	1.42	1.39	1.37	1.32	1.28	1.23	1.19	1.15	1.1	1.05	1.02	0.98
5.17	49.5	1.61	1.58	1.55	1.5	1.46	1.4	1.36	1.31	1.25	1.2	1.16	1.12
5.33	55.5	1.81	1.78	1.74	1.68	1.63	1.57	1.52	1.47	1.4	1.34	1.3	1.25
5.50	62.5	2.04	2	1.96	1.89	1.84	1.77	1.71	1.65	1.58	1.51	1.47	1.41
5.67	70.5	2.3	2.26	2.21	2.14	2.07	2	1.93	1.86	1.78	1.71	1.66	1.59
5.83	77.5	2.53	2.48	2.43	2.35	2.28	2.19	2.12	2.05	1.95	1.88	1.82	1.75
6.00	83.5	2.72	2.67	2.62	2.53	2.45	2.36	2.29	2.2	2.1	2.02	1.96	1.89
6.17	88.5	2.89	2.83	2.78	2.68	2.6	2.5	2.42	2.34	2.23	2.14	2.08	2
6.33	91.5	2.98	2.93	2.87	2.77	2.69	2.59	2.51	2.42	2.31	2.21	2.15	2.07
6.50	93.5	3.05	2.99	2.94	2.83	2.75	2.65	2.56	2.47	2.36	2.26	2.2	2.11
6.67	94.5	3.08	3.02	2.97	2.86	2.78	2.67	2.59	2.49	2.38	2.29	2.22	2.14
6.83	95.5	3.11	3.06	3	2.89	2.81	2.7	2.62	2.52	2.41	2.31	2.24	2.16
7.00	96.3	3.14	3.08	3.02	2.92	2.83	2.73	2.64	2.54	2.43	2.33	2.26	2.18
7.17	97	3.16	3.1	3.05	2.94	2.85	2.75	2.66	2.56	2.44	2.35	2.28	2.19
7.33	97.5	3.18	3.12	3.06	2.95	2.87	2.76	2.67	2.57	2.46	2.36	2.29	2.2
7.50	97.9	3.19	3.13	3.07	2.97	2.88	2.77	2.68	2.58	2.47	2.37	2.3	2.21
7.67	98.2	3.2	3.14	3.08	2.98	2.89	2.78	2.69	2.59	2.47	2.38	2.31	2.22
7.83	98.5	3.21	3.15	3.09	2.98	2.9	2.79	2.7	2.6	2.48	2.38	2.31	2.23
8.00	98.7	3.22	3.16	3.1	2.99	2.9	2.79	2.7	2.61	2.49	2.39	2.32	2.23
8.17	98.9	3.22	3.16	3.11	3	2.91	2.8	2.71	2.61	2.49	2.39	2.32	2.24
8.33	99	3.23	3.17	3.11	3	2.91	2.8	2.71	2.61	2.49	2.4	2.33	2.24
8.50	99.1	3.23	3.17	3.11	3	2.91	2.8	2.72	2.62	2.5	2.4	2.33	2.24
8.67	99.2	3.23	3.17	3.11	3.01	2.92	2.81	2.72	2.62	2.5	2.4	2.33	2.24
8.83	99.3	3.24	3.18	3.12	3.01	2.92	2.81	2.72	2.62	2.5	2.4	2.33	2.24
9.00	99.4	3.24	3.18	3.12	3.01	2.92	2.81	2.72	2.62	2.5	2.41	2.34	2.25
9.17	99.5	3.24	3.10	3.12	3.01	2.95	2.82	2.75	2.03	2.51	2.41	2.34	2.25
9.55	99.0	3.25	3.19	3.13	3.02	2.95	2.82	2.75	2.03	2.51	2.41	2.34	2.25
9.50	99.7	3.23	2 10	2.12	3.02	2.95	2.82	2.75	2.03	2.51	2.41	2.34	2.25
9.67	99.8	3.25	3.19	3.13	3.02	2.95	2.82	2.75	2.03	2.51	2.42	2.35	2.20
5.65	100	3.20	3.2	2 14	3.03	2.94	2.03	2.74	2.04	2.52	2.42	2.35	2.20
10.00	100	3.20	3.2	3.14	3.03	2.94	2.03 2.92	2.74	2.04	2.52	2.42	2.33	2.20
10.17	100	3.20	3.2	2 14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.35	2.20
10.55	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.33	2.20
10.50	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.33	2.20
10.07	100	2.20	3.2	2 14	3.03	2.54	2.03 2 92	2.74	2.04	2.52	2.42	2.33	2.20
11.00	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.35	2.20
11.00	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.33	2.20
11 33	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.33	2.20
11.55	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.33	2.20
11.67	100	3.26	3.2	3.14	3.03	2.94	2.83	2.74	2.64	2.52	2.42	2.35	2.26
11.83	100	3.20	3.2	3.14	3.03	2.54	2.03	2.74	2.04	2.52	2.42	2.35	2.20
12.00	100	3.26	3,2	3.14	3.03	2.94	2.83	2.74	2.64	2.52	2.42	2.35	2.26
		5.20	5.2	2.27	5.00	T		T	T	2.52	20.02	2.00	0

200-Year Local Storm													
12 Hour Rainfall Dept	th (in)	7.65	Atlas 14, 2	00 Year									
Storm Size (sq mi)		10	20	30	50	70	95	120	150	200	250	300	400
ARF %		98	96.1	94.4	91.1	88.4	85	82.4	79.4	75.6	72.8	70.7	68
Rainfall Depth (in)		7.5	7.35	7.22	6.97	6.76	6.5	6.3	6.07	5.78	5.57	5.41	5.2
Storm Time (hours)	Cumulative %												
0	0	0	0	0	0	0	0	0	0	0	0	0	0
0.17	0.1	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.33	0.2	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
0.50	0.4	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.02	0.02	0.02	0.02	0.02
0.67	0.6	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03	0.03	0.03
0.83	0.8	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04
1.00	1	0.08	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.05	0.05
1.17	1.3	0.1	0.1	0.09	0.09	0.09	0.08	0.08	0.08	0.08	0.07	0.07	0.07
1.33	1.5	0.11	0.11	0.11	0.1	0.1	0.1	0.09	0.09	0.09	0.08	0.08	0.08
1.50	1.7	0.13	0.12	0.12	0.12	0.11	0.11	0.11	0.1	0.1	0.09	0.09	0.09
1.67	1.9	0.14	0.14	0.14	0.13	0.13	0.12	0.12	0.12	0.11	0.11	0.1	0.1
1.65	2.2	0.17	0.10	0.10	0.15	0.15	0.14	0.14	0.15	0.15	0.12	0.12	0.11
2.00	2.0	0.2	0.19	0.19	0.10	0.16	0.17	0.10	0.10	0.15	0.14	0.14	0.14
2.17	3.1	0.25	0.25	0.22	0.22	0.21	0.2	0.2	0.19	0.16	0.17	0.17	0.10
2.55	3.0	0.27	0.20	0.20	0.23	0.24	0.23	0.25	0.22	0.21	0.2	0.19	0.19
2.30	4.2	0.32	0.31	0.5	0.25	0.20	0.27	0.20	0.23	0.24	0.23	0.23	0.22
2.07	5	0.36	0.37	0.30	0.33	0.34	0.33	0.32	0.3	0.25	0.20	0.27	0.20
3.00	75	0.45	0.55	0.43	0.42	0.51	0.35	0.30	0.30	0.33	0.33	0.32	0.31
3.17	9	0.50	0.55	0.54	0.52	0.51	0.45	0.47	0.40	0.45	0.42	0.41	0.33
3.33	10.5	0.00	0.00	0.05	0.03	0.01	0.55	0.57	0.55	0.52	0.5	0.45	0.47
3.50	12.5	0.75	0.92	0.70	0.73	0.85	0.80	0.00	0.04	0.01	0.50	0.57	0.55
3.67	14.5	1.09	1 07	1.05	1 01	0.05	0.94	0.75	0.88	0.84	0.81	0.08	0.05
3.83	17	1.05	1.07	1.03	1.01	1 15	1 11	1 07	1.03	0.04	0.01	0.70	0.75
4.00	19.5	1.46	1.43	1.41	1.36	1.32	1.27	1.23	1.18	1.13	1.09	1.05	1.01
4.17	22.5	1.69	1.65	1.62	1.57	1.52	1.46	1.42	1.37	1.3	1.25	1.22	1.17
4.33	25.5	1.91	1.87	1.84	1.78	1.72	1.66	1.61	1.55	1.47	1.42	1.38	1.33
4.50	29.5	2.21	2.17	2.13	2.06	1.99	1.92	1.86	1.79	1.71	1.64	1.6	1.53
4.67	33.5	2.51	2.46	2.42	2.33	2.26	2.18	2.11	2.03	1.94	1.87	1.81	1.74
4.83	38.5	2.89	2.83	2.78	2.68	2.6	2.5	2.43	2.34	2.23	2.14	2.08	2
5.00	43.5	3.26	3.2	3.14	3.03	2.94	2.83	2.74	2.64	2.51	2.42	2.35	2.26
5.17	49.5	3.71	3.64	3.57	3.45	3.35	3.22	3.12	3	2.86	2.76	2.68	2.57
5.33	55.5	4.16	4.08	4.01	3.87	3.75	3.61	3.5	3.37	3.21	3.09	3	2.89
5.50	62.5	4.69	4.59	4.51	4.36	4.23	4.06	3.94	3.79	3.61	3.48	3.38	3.25
5.67	70.5	5.29	5.18	5.09	4.91	4.77	4.58	4.44	4.28	4.07	3.93	3.81	3.67
5.83	77.5	5.81	5.7	5.6	5.4	5.24	5.04	4.88	4.7	4.48	4.32	4.19	4.03
6.00	83.5	6.26	6.14	6.03	5.82	5.64	5.43	5.26	5.07	4.83	4.65	4.52	4.34
6.17	88.5	6.64	6.5	6.39	6.17	5.98	5.75	5.58	5.37	5.12	4.93	4.79	4.6
6.33	91.5	6.86	6.73	6.61	6.38	6.19	5.95	5.76	5.55	5.29	5.1	4.95	4.76
6.50	93.5	7.01	6.87	6.75	6.52	6.32	6.08	5.89	5.68	5.4	5.21	5.06	4.86
6.67	94.5	7.09	6.95	6.82	6.59	6.39	6.14	5.95	5.74	5.46	5.26	5.11	4.91
6.83	95.5	7.16	7.02	6.9	6.66	6.46	6.21	6.02	5.8	5.52	5.32	5.17	4.97
7.00	96.3	7.22	7.08	6.95	6.71	6.51	6.26	6.07	5.85	5.57	5.36	5.21	5.01
7.17	97	7.28	7.13	7	6.76	6.56	6.31	6.11	5.89	5.61	5.4	5.25	5.04
7.33	97.5	7.31	7.17	7.04	6.8	6.59	6.34	6.14	5.92	5.64	5.43	5.27	5.07
7.50	97.9	7.34	7.2	7.07	6.82	6.62	6.36	6.17	5.94	5.66	5.45	5.3	5.09
7.67	98.2	7.37	7.22	7.09	6.84	6.64	6.38	6.19	5.96	5.68	5.47	5.31	5.11
7.83	98.5	7.39	7.24	7.11	6.87	6.66	6.4	6.21	5.98	5.69	5.49	5.33	5.12
8.00	98.7	7.4	7.25	7.13	6.88	6.67	6.42	6.22	5.99	5.7	5.5	5.34	5.13
8.17	98.9	7.42	7.27	7.14	6.89	6.69	6.43	6.23	6	5.72	5.51	5.35	5.14
8.33	99	7.43	7.28	7.15	6.9	6.69	6.44	6.24	6.01	5.72	5.51	5.36	5.15
8.50	99.1	7.43	7.28	7.16	6.91 C OC	6.7	6.44 C 45	ь.24 с.25	b.U2	5./3	5.52	5.36	5.15
8.0/ 0.00	99.2	7.44	7.29	7.16	6.91 C 02	0./1	0.45 C 45	0.25	6.02	5./3	5.53	5.37	5.16
0.05	39.3	7.45	7.3	7.1/	6.92	6./1	6.45 C AC	6.26	6.03	5.74	5.55	5.3/	5.10
9.00	99.4 00 F	7.40	7.31	7.10	0.95	6.72	0.40	6.20	6.03	5.75	5.54	5.36	5.17
9.17	99.5	7.40	7.51	7.10	6.94	6.73	6.47	6.27	6.04	5.75	5.54	5.36	5.17
9.55	99.0	7.47	7.32	7.19	6.95	6.74	6.49	6.28	6.05	5.70	5.55	5.39	5.10
0.67	00.9	7.40	7.33	7.2	6.05	6.74	6.40	6 20	6.05	5.70	5.55	5.55	5.10 E 10
9.07	93.0 QQ Q	7.49	7.34	7.21	6 96	6.75	6 40	6 20	6.00	5.77	5.50	5.4 5 /	5.19
10.00	100	7.49	7.34	7.21	6.97	6.76	6.5	63	6.07	5.79	5.50	5.4	5.19
10.00	100	7.5	7.35	7.22	6.97	6.76	6.5	6.2	6.07	5.70	5.57	5.41 5.41	5.2
10.33	100	7.5	7 25	7.22	6.97	6 76	6.5	6.2	6.07	5.70	5.57	5.41 5.41	5.2
10.55	100	7.5	7 35	7.22	6 97	6 76	6.5	63	6.07	5.78	5.57	5 41	5.2
10.50	100	7.5	7 35	7.22	6.97	6 76	6.5	63	6.07	5.78	5.57	5 41	5.2
10.83	100	75	7 35	7 22	6 97	6 76	6.5	6 3	6.07	5.78	5.57	5 41	5.2
11 00	100	7.5	7.35	7.22	6 97	6 76	6.5	6.3	6.07	5.78	5.57	5.41 5.41	5.2
11.00	100	7.5	7 35	7.22	6.97	6 76	6.5	63	6.07	5.78	5.57	5 41	5.2
11 33	100	75	7 35	7 22	6 97	6 76	6.5	63	6.07	5.78	5.57	5 41	5.2
11.50	100	75	7 35	7 22	6 97	6 76	6.5	63	6.07	5 78	5 57	5 41	5.2
11.67	100	7.5	7.35	7.22	6.97	6.76	6.5	6.3	6.07	5.78	5.57	5.41	5.2
11.83	100	7.5	7.35	7.22	6.97	6.76	6.5	6.3	6.07	5.78	5.57	5.41	5.2
12.00	100	7.5	7.35	7.22	6.97	6.76	6.5	6.3	6.07	5.78	5.57	5.41	5.2