

CAMP MORENA



Inside this issue:

Camp Morena Source Water	1
About Drinking Water	1
Definitions & Abbreviations	3
Water Quality Tables	4
Violations & Exceedances	4
Water Complaints	4

For additional information:

California Division of
Drinking Water
waterboards.ca.gov

US EPA Safe Drinking
Water Hotline
(800) 426 - 4791
<http://www.epa.gov/safewater>

Public Works Department
(PWD) Environmental
Division, Drinking Water
Program
(619) 545-1127



The source of Camp Morena's water is from groundwater.

CAMPO, CALIFORNIA 2022 CONSUMER CONFIDENCE REPORT

Naval Base Coronado (NBC) is committed to providing you drinking water that is safe and reliable at Camp Morena (CM). NBC believes that providing you with accurate information about your water is the best way to assure that your water is safe and reliable.

The Consumer Confidence Report (CCR) for your installation is not required by the Regulation, but we are distributing to provide you information related to the quality of your drinking water in 2022. The purpose of this annual report is to advise consumers of where their water comes from, provide water quality data, advance greater understanding of drinking water, and heighten awareness to conserve water resources.

Español: *Este informe contiene información muy importante sobre su agua de beber. Favor de comunicarse CAMP MORENA a kevin.b.dixon.civ@us.navy.mil para asistirlo en español.*

CAMP MORENA SOURCE WATER

The City of San Diego owns the land on which Naval Facilities Engineering Systems Command Southwest (NAVFAC SW) operates the potable water system at CM. The potable water system consists of one City of San Diego owned supply well and water treatment system, and Navy Owned water distribution system with five storage tanks. Treatment consists of a filtration system that removes iron and manganese from the drinking water, in addition to a chlorinator that disinfects the drinking water.

ABOUT DRINKING WATER

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances (contaminants) resulting from the presence of animals or from human activity. Contaminants in source water may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban storm water runoff, residential uses, and many other types of activities. Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals which are by-products of industrial processes and petroleum production, and can come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) establishes limits for contaminants in bottled water, which must provide the same protection for public health.

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center of Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NBC is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by **flushing your tap for 30 seconds to 2 minutes** or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you have questions about your water, please contact the PWD Environmental Division at (619) 545-1127. For more information regarding the Navy's Lead and Copper Rule Sampling Program, please visit <https://cnrsw.cnic.navy.mil/Operations-and-Management/Environmental-Support/Drinking-Water-Quality-Information/Lead-and-Copper-Rule-Sampling-program/>.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

What are per- and polyfluoroalkyl substances and where do they come from?

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industrial and consumer products around the globe, including in the U.S., for decades. Due to their widespread use and environmental persistence, most people in the United States have been exposed to certain PFAS. PFAS have been used to make coatings and products that are used as oil and water repellents for carpets, clothing, paper packaging for food, and cookware. They are also contained in some foams (aqueous film-forming foam or AFFF) used for fighting petroleum fires.

Is there a federal or California regulation for PFAS in drinking water?

There is currently no federal drinking water standard for any PFAS compounds. In May 2016, the U.S. Environmental Protection Agency (EPA) established a lifetime drinking water health advisory (HA) level at 70 parts per trillion (ppt) for individual or combined concentrations of perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS). Both chemicals are types of PFAS.

In California, there is not a PFAS drinking water regulation.

The Department of Defense (DoD) issued a policy in 2020 to monitor drinking water for PFAS at all DoD owned and operated consecutive water systems. A consecutive system is a public water system that buys or otherwise receives some or all of its finished water from a wholesale system City of San Diego (Purveyor). The DoD policy states that if water sampling results confirm that drinking water contains PFOA and PFOS at individual or combined concentrations greater than the 2016 EPA HA level of 70 ppt, water systems will request the Purveyor take immediate action to decrease the PFAS levels to below 70 ppt.

What about the EPA's 2022 interim Health Advisories or proposed regulations?

EPA issued interim Health Advisories for PFOS and PFOA in 2022. However these newer levels are below quantifiable limits (i.e., below detection levels). EPA is expected to issue a proposed regulation on PFAS drinking water standards for public comment in the next few months. DoD looks forward to the clarity that a nationwide regulatory standard for PFOS and PFOA in drinking water will provide.

In addition, EPA issued interim Health Advisories for PFOS and PFOA in 2022. However, these newer levels are below quantifiable limits (i.e., below detection levels).

In anticipation of this EPA drinking water regulation and to account for emerging science that shows potential health effects of PFOS and PFOA at levels lower than 70 ppt, DoD is evaluating its efforts to address PFAS in drinking water, and what actions we can take to be prepared to incorporate this standard, such as reviewing our current data and collecting additional sampling where necessary. DoD remains committed to communicating and engaging with our communities throughout this process.

Has Camp Morena tested its water for PFAS?

Yes. In June 2021, samples were collected from the Quarterdeck.

We are informing you that PFOA was detected, but below the 2016 EPA HA. Other PFAS compounds covered by the sampling method were detected above the method reporting limit (MRL) but EPA does not have a HA for these compounds at this time. The results are provided in Table 1.

Table 1. PFAS Compound Detected – Camp Morena (Quarterdeck)

Analyte	PFAS Compound	Units	Result (ppt) 06/10/2021
Perfluoro-butane Sulfonic Acid	PFBS	ng/L	2.9
Perfluoro-hexane Sulfonic Acid	PFHxS	ng/L	2.3
Perfluoro-octanoic Acid	PFOA	ng/L	3.0

DEFINITIONS AND ABBREVIATIONS

Contaminants in your drinking water are routinely monitored according to Federal and State regulations. The table on the following pages shows the results of monitoring 2022. In the tables and elsewhere in this report, you may find some unfamiliar terms and abbreviations. The following definitions are provided to better understand these terms.

Maximum Contaminant Level (MCL), The highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal (MCGL), The level of a contaminant in drinking water below which there is no known or expected risk to health.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): Secondary MCLs (SMCLs) for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect health at MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

DLR: Detection limit for reporting

Regulatory Action Level (AL): The concentration of a contaminant, if exceeded, triggers treatment or other requirements which a system must follow.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

N/A: not applicable

NTU: Nephelometric Turbidity Unit (a measure of turbidity in water)

ppm: parts per million (or 1 drop in 1 million gallons; mg/L)

ppb: parts per billion (or 1 drop in 1 billion gallons; ug/L)

pCi/L: picocuries per liter (a measure of radiation)

WATER QUALITY DATA

The tables below list only those contaminants that were present in your drinking water at levels detectable by laboratory equipment. Unless otherwise noted, the data presented in these tables is from testing done in 2022. We are required to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA sets the Maximum Contaminant

Levels (MCLs) and the Maximum Contaminant Level Goals (MCLGs) as listed in the tables below. The Regulated Substances Table and Unregulated Substances Table are provided for your information and as required by the Consumer Confidence Rule.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacterial detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Violation (Yes/No)	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	0	0	1 positive monthly sample ^(a)	0	No	Naturally present in the environment
Total Fecal Coliform or <i>E. Coli</i> (state Total Coliform Rule)	0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	No	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	0	0	(b)	0	No	Human and animal fecal waste

(a) Two or more positive monthly samples is a violation of the MCL.

(b) The Revised Total Coliform Rule established the following Primary Maximum Contamination Level (PMCL): In compliance unless (i) the waterworks has an *E. coli* positive repeat sample following a total coliform positive routine sample; (ii) the waterworks has a total coliform positive repeat sample following an *E. coli* positive routine sample; (iii) the waterworks owner fails to take all required repeat samples following an *E. coli* positive routine sample; or (iv) the waterworks owner fails to test for *E. coli* when any repeat sample tests positive for total coliform

TABLE 3 – CHEMICAL PARAMETERS

Chemical or Constituent (and reporting units)	Sample Year	Level Detected (Average)	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Violation (Yes/No)	Typical Sources
Nitrate as Nitrogen	2022	0.83	Single Sample	10	10	No	Erosion of natural deposits, runoff
Nitrite as Nitrogen	2022	ND	Single Sample	1	1	No	Erosion of natural deposits, runoff

Summary Information for Violation of a MCL, MRDL, AL, NL, or TT

There are no drinking water violations to report for 2022.

WATER COMPLAINTS

Does the filter on your fountain or faucet need to be changed? Please coordinate with your building monitor or facility manager. Make sure filters are marked with the date they were changed out and keep a logbook.

Does your water have an odd taste, color, odor, suspended solids, or do you suspect a water-related illness? Please call the NBC Drinking Water Program Manager at (619) 545-1127 or After Hours Trouble Desk at (619) 556-1309 with details (i.e. building number, concern, complaint POC etc.).

QUESTIONS

Please contact NBC Water Quality Program Manager at (619) 545-1127 or email the NBC Public Affairs Officer at kevin.b.dixon.civ@us.navy.mil if you would like additional information on sampling and monitoring efforts at Camp Morena. Sampling data is available to be reviewed at the website below

https://sdwis.waterboards.ca.gov/PDWW/JSP/WaterSystemDetail.jsp?tinwsys_is_number=9868&tinwsys_st_code=CA&wsnu_mber=CA3705061

To access this report electronically, please visit the Commander, Navy Region Southwest website at:

<https://cnrsw.cnic.navy.mil/Operations-and-Management/Environmental-Support/Drinking-Water-Quality-Information/>.