



## Annual Consumer Confidence Report for Calendar Year 2022 on the Quality of Drinking Water for the Centroid Water System

---

### Is the Centroid drinking water safe?

This Annual Consumer Confidence Report presents the results of our drinking water system's quality monitoring for the calendar year January 1st to December 31<sup>st</sup>, 2022. During the entire calendar year 2022, the Centroid drinking water system met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. NASF vigilantly safeguards its drinking water supplies and we are proud to report that our drinking water system did not violate a maximum contaminant level or any other water quality standard.

### Where does my water come from?

NASF owns a groundwater well located inside the installation perimeter. Groundwater from this deep well comes from an aquifer over 500 feet below the surface. Water is drawn from this well and delivered via pipeline to the Centroid Arsenic Treatment Facility. This treatment facility removes arsenic prior to distribution to Centroid Facilities using an adsorption treatment system followed by disinfection by sodium hypochlorite.

### Why are there contaminants in some drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- Inorganic contaminants such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses;
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and
- Radioactive contaminants, which can be naturally occurring, or that may be the result of oil and gas production or mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. NASF drinking water is routinely tested for 88 water contaminants from the National Primary Drinking Water Regulations (NPDWRs or primary standards) and for 14 from the National Secondary Drinking Water Regulations (NSDWRs or secondary standards). The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by accessing the EPA website at <http://water.epa.gov/lawsregs/guidance/sdwa/basicinformation.cfm>.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised individuals such as people undergoing chemotherapy for cancer, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, and some elderly and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Source Water Assessment and its availability

The Nevada Bureau of Safe Drinking Water (BSDW) completed their Vulnerability Assessment Program (VAP) Public Water System Report of NASF source water in December 23, 2019. They reported that our water system is compliant with all State of Nevada and Federal water quality standards. The water system is potentially vulnerable to inorganic compounds (IOC) typically associated natural deposits, fertilizers, septic systems, and asbestos. A full copy of the Vulnerability Assessment is available for viewing at the BSDW, Carson City Office.

### **\*\*Additional Safe Drinking Water Information\*\***

#### **Lead**

While your water meets the EPA's standard for Lead, if present at elevated levels this contaminant can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

*What can I do to minimize exposure to lead?*

Flush. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. You may need to flush longer if your building has been shut down or experienced reduced occupancy.

Use Cold Water. Hot water dissolves lead more quickly than cold water, so use cold water to prepare food and drinks.

Clean Your Aerator. Metal debris can be trapped on the aerator screens on water outlets, especially if construction or plumbing work may have occurred in your area. Simply twist off the aerator (may need a wrench and vinegar if there is build-up), carefully tap and clean any debris which may be caught on the filtration screen, and reinstall.

If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### **Arsenic**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

#### **COVID-19**

The transfer of COVID-19 between humans is primarily from the inhalation of droplets containing the virus from other people. It is suspected as occurring from people touching their face with their hands after their hands have touched a contaminated surface. The virus is readily killed by chlorine in water treatment, and is not known to be transmitted through drinking water. Therefore, no sampling and analysis for COVID-19 is conducted in drinking water.

## **CY2022 Consumer Confidence Report (CCR) Language Regarding PFAS**

### **What are per- and polyfluoroalkyl substances and where do they come from?**

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS are used in a variety of industrial and consumer products around the globe, including in the U.S., for decades. Due to their widespread use and environmental persistence, most people in the United States are exposed to certain PFAS. PFAS make coatings and products that are used as oil and water repellents for carpets, clothing, paper packaging for food, and cookware. They are also contained in some foams (aqueous film-forming foam or AFFF) used for fighting petroleum fires.

### **Is there a federal or State of Nevada regulation for PFAS in drinking water?**

There is currently no federal drinking water standard for any PFAS compounds. In May 2016, the U.S. Environmental Protection Agency (EPA) established a lifetime drinking water health advisory (HA) level at 70 parts per trillion (ppt) for individual or combined concentrations of perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS). Both chemicals are types of PFAS.

In Nevada, there is not a PFAS drinking water regulation.

The Department of Defense (DoD) issued a policy in 2020 to monitor drinking water for PFAS at all DoD owned and operated consecutive water systems. A consecutive system is a public water system that buys or otherwise receives some or all of its finished water from a system such as the City of Fallon. The DoD policy states that if water sampling results confirm that drinking water contains PFOA and PFOS at individual or combined concentrations greater than the 2016 EPA HA level of 70 ppt, water systems will request the Purveyor take immediate action to decrease the PFAS levels to below 70 ppt.

### **What about the EPA's 2022 interim Health Advisories or proposed regulations?**

EPA issued interim Health Advisories for PFOS and PFOA in 2022. However, these newer levels are below quantifiable limits (i.e. below detection levels). EPA is expected to issue a proposed regulation on PFAS drinking water standards for public comment in the next few months. DoD looks forward to the clarity that a nationwide regulatory standard for PFOS and PFOA in drinking water will provide.

In addition, EPA issued interim Health Advisories for PFOS and PFOA in 2022. However, these newer levels are below quantifiable limits (i.e., below detection levels).

In anticipation of this EPA drinking water regulation, and to account for emerging science that shows potential health effects of PFOS and PFOA at levels lower than 70 ppt, DoD is evaluating its efforts to address PFAS in drinking water, and what actions we can take to be prepared to incorporate this standard, such as reviewing our current data and collecting additional sampling where necessary. DoD remains committed to communicating and engaging with our communities throughout this process.

### **Has Naval Air Station Fallon tested its water for PFAS?**

Yes. On November 4, 2020 samples were collected following the arsenic treatment system.

We are pleased to report that drinking water testing results were below the Method Reporting Limit (MRL) of 0.0020 ppb or 2 parts per trillion (ppt) for all 18 PFAS compounds covered by the sampling method. This means that PFAS were not detected in your water system. In accordance with DoD policy, the water system will be resampled every three years for your continued protection.

### **Whom can I contact for more information?**

If you have any questions regarding the information presented in this report or NASF drinking water in general, please feel free to contact Mr. Harry Little, P.E. at the NASF Public Works Environmental Division. His email address is [harry.l.little5.civ@us.navy.mil](mailto:harry.l.little5.civ@us.navy.mil). He also has a copy of the Vulnerability Assessment completed by the Nevada Bureau of Safe Drinking Water dated December 23, 2019 that is referenced above.

## Water Quality Tables

Presented below are the water quality tables. Unless otherwise noted, the data presented in these tables is from testing done in the 2022 calendar year. The tables below list all of the drinking water contaminants that were detected during the most recent tests. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The tables show that our system met all requirements during the 2022 calendar year. In addition to these data, routine sampling and analyses for residual chlorine and total coliform bacteria are conducted monthly to verify that the drinking water is safe. The data is reported to the Nevada Department of Environmental Protection - Safe Drinking Water Division on a routine basis. For brevity, those analytical data have not been included in this report.

### \*\*\*How to Read the tables\*\*\*

The tables on the following pages show contaminants (and their regulatory limits) detected in your drinking water. *Contaminants not detected are not listed.*

To view data about the water delivered to your home or office, look at the tables and find the column “Your Water After Treatment.” Compare this data with the maximum allowable amount of each contaminant, found in the column labeled “MCL, TT, MRDL, SMCL, or AL.” For example, the average detected amount of Haloacetic Acids (HAA5) (a by-product of disinfecting your water) is 3.1 ppb. This compares to the MCL of 60 ppb. Because the detected level of HAA5 is less than the MCL, there is no violation of drinking water standards set by the EPA and adopted by the State of Nevada. Therefore, a “No” was placed in the “Violation” column of the table.

The “Terms and Abbreviations” section at the end of this report defines the terminology used in the following tables.

## Centroid Distribution System Water Quality Data Tables

### Disinfection Byproducts

The chemical compounds listed below are the result of chlorinating the drinking water for disinfection.

<u>Contaminants</u>	<u>MCL, TT, or MRDL</u>	<u>Your Water After Treatment</u>	<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
HAA5 (Haloacetic Acids) (ppb)	60	2.3	11/01/2022	No	By-product of drinking water disinfection by chlorination.
TTHMs [Total Trihalomethanes] (ppb)	80	29	11/01/2022	No	By-product of drinking water disinfection by chlorination.

### Inorganic Contaminants

The inorganic contaminants listed below are for the two items that are commonly evaluated: copper and lead. The drinking water was sampled from five locations, Building A, Building B Men’s Room, Building C Kitchen Sink, Building C 113 Men’s Room and Building D Kitchen.

<u>Contaminants</u>	<u>MCL or MRDLG</u>	<u>AL</u>	<u>Your Water After Treatment</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
Inorganic Contaminants							
Copper – action level at consumer taps (ppb)	1000	1,300	3	9/21/22	0	No	Building plumbing systems corrosion; erosion of natural deposits; leaching of wood preservatives.
Lead – action level at consumer taps (ppb)	0	15	<1	9/21/22	0	No	Building plumbing systems corrosion; erosion of natural deposits.

### Primary Drinking Water Standards (Regulated Contaminants)

The data table below presents the results from testing completed for Primary Drinking Water Standards, which are enforceable standards on regulated contaminants. Contaminants not detected are not listed. All data listed are in parts per million (ppm) except for arsenic, chromium and selenium which are reported in part per billion (ppb).

#### Inorganic Contaminants

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL, TT, or MRDL</u>	<u>Water After Treatment</u>	<u>Range</u>		<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>			
Arsenic (ppb)	0	10	3 (average *)	2	3	3/30/22 6/28/22 9/21/22 10/18/22	No	Erosion of natural deposits; runoff from orchards.
Chromium (ppb)	100	100	7	NA		9/20/22	No	Erosion of natural deposits
Fluoride (ppb)	2,000	4,000	1,500	NA		9/20/22	No	Erosion of natural deposits
Nickel (ppb)	100	100	6	NA		2019	No	Erosion of natural deposits
Nitrate as N (ppb)	10,000	10,000	160	NA		9/20/22	No	Runoff from fertilizer use; erosion of natural deposits
Selenium (ppb)	50	50	<5	NA		9/20/22	No	Erosion of natural deposits

### Secondary Drinking Water Standards

The Secondary Drinking Water Standards are in primarily for aesthetics such as taste and odor in drinking water. These standards are not enforceable, but are guidelines only. Contaminants not detected are not listed.

<u>Contaminants</u>	<u>SMCL</u>	<u>Water After Treatment</u>	<u>Sample Date</u>	<u>SMCL Exceeded</u>	<u>Typical Source</u>
Chloride (ppb)	400,000	49,000	9/20/22	No	Runoff/leaching from natural deposits

#### Terms & abbreviations used in this report

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the Maximum Contaminant Level Goals (MCLGs) as feasible using the best available treatment technology. These are enforceable standards.
- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. This is not enforceable.
- **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL):** The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Secondary Maximum Contaminant Level (SMCL):** Secondary standards are established as a guideline by the State to assist public water systems in managing drinking water aesthetic considerations such as color, odor, and taste. Secondary standards are not enforced by the EPA, and are not considered a health risk at the SMCL. Above the SMCL these constituents may cause poor taste, color/clarity or odor, though the water is safe to drink.
- **Maximum Residual Disinfection Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **NA:** Not available/applicable
- **ND:** Non detect
- **ppb:** Parts per billion or micrograms per liter
- **ppm:** Parts per million or milligrams per liter
- **pCi/L:** Picocuries per liter (a measure of radiation)
- **TON:** Threshold Odor Number
- **MFL:** Million fibers per liter