

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
Chesteron									
Teen-Ctr-S1	1.49	DRINKING	19H49501	8/13/2019	NO				
Mens-RR-S1	0.717	WASHING	19H49502	8/13/2019	NO				
Mens-RR-S2	0.816	WASHING	19H49503	8/13/2019	NO				
Mens-RR-S3	0.937	WASHING	19H49504	8/13/2019	NO				
Woman-RR-S1	0.827	WASHING	19H49505	8/13/2019	NO				
Woman-RR-S2	0.775	WASHING	19H49506	8/13/2019	NO				
Woman-RR-S3	0.777	WASHING	19H49507	8/13/2019	NO				
Kitchen-S1	0.536	COOKING	19H49508	8/13/2019	NO				
BB1	0.503	DRINKING	19H49509	8/13/2019	NO				
BB2	0.436	DRINKING	19H49510	8/13/2019	NO				